



Errata

## NFPA<sup>®</sup> 59A

# Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)


2009 Edition

**Reference:** Figure A.10.7.2(d)

**Errata No.:** 59A-09-1

The Committee on Liquefied Natural Gas notes the following error in the 2009 edition of NFPA 59A, *Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)*.

1. In Figure A.10.7.2(d) change the figure to show that the text tag for the darker shaded circle should be 5 ft (1.5 m) as follows:



**Figure A.10.7.2(d) Full Containment Container.**

**Issue Date:** January 3, 2012

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see [www.nfpa.org/codelist](http://www.nfpa.org/codelist))

Copyright © 2012 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION