

**Final Results**  
**Floor Action on Certified Amending Motions**  
**Documents for the June 2010 Association**  
**Technical Meeting**

**NFPA 18, NFPA 25, NFPA 45, NFPA 53, NFPA 58,  
NFPA 70, NFPA 86, NFPA 96, NFPA 204, NFPA 214,  
NFPA 276, NFPA 303, NFPA 502, NFPA 505, NFPA 654**

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
45-1	2:29:00PM 3:05:50PM	8.10.1	William A. Eckholm, Firetrace International	Accept Proposal 45-20	Motion Failed (87-119)

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 654, Standard for the Prevention of Fire and Dust Explosions from the Manufacturing, Processing, and Handling of Combustible Particulate Solids A2010*

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>654-1</b>	3:07:50PM 3:28:28PM	3.3.x Dust Fire Hazard Areas	John M. Cholin, J. M. Cholin Consultants Inc.	Accept Comment 654-5	Motion Passed
<b>654-2</b>	3:29:50PM	3.3.4 Combustible Dust	David B. Wechsler, The Dow Chemical Company	Reject an Identifiable Part of Comment 654-6 The rejection of the identifiable part results in the rejection of the changes to the definition of "Combustible Dust".	Motion not pursued
		3.3.4 Combustible Dust	David B. Wechsler, The Dow Chemical Company	Reject an Identifiable Part of Comment 654-7 The rejection of the identifiable part results in the rejection of the changes to the definition of "Combustible Dust".	
	3:41:09PM	3.3.4 Combustible Dust	David B. Wechsler, The Dow Chemical Company	Reject an Identifiable Part of Comment 654-8 The rejection of the identifiable part results in the rejection of the changes to the definition of "Combustible Dust".	
<b>654-3</b>	3:42:27PM 4:09:09PM	6.1 (New)	John M. Cholin, J. M. Cholin Consultants Inc.  Donald Hirsch, Iron Mountain  Sam W. Francis, American Forest & Paper Association	Return a portion of a Report in the form on identifiable part of a proposal 654-15 and related comment 654-10 The identifiable part that is returned is new proposed Section 6.1.	Motion Passed
<b>654-4</b>	NA	6.1.3 and 6.1.4	Sam W. Francis, American Forest & Paper Association Francis is the Desig. Rep*. for Lancey	Accept Comment 654-24	Motion not pursued
<b>654-5</b>	NA	6.1.3, 6.1.4, and 6.1.5	Sam W. Francis, American Forest & Paper Association Francis is the Desig. Rep*. for Lancey	Accept Comment 654-31	Motion not pursued

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 654, Standard for the Prevention of Fire and Dust Explosions from the Manufacturing, Processing, and Handling of Combustible Particulate Solids A2010 (continued)*

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>654-6</b>	NA	6.1.8 [new 7.13.1.7.3]	John M. Cholin, J. M. Cholin Consultants Inc.	Accept Comment 654-33	Motion tabled
<b>654-7</b>	NA	6.1.8(2)	Sam W. Francis, American Forest & Paper Association Francis is the Desig. Rep* for Lancey	Accept Comment 654-36	Motion not pursued
<b>654-8</b>	NA	6.2.3.1 and 6.2.3.2	John M. Cholin, J. M. Cholin Consultants Inc.	Accept Proposal 654-7	Motion tabled
		6.2.3.1 and 6.2.3.2	John M. Cholin, J. M. Cholin Consultants Inc.	Accept Proposal 654-10	
<b>654-9</b>	4:14:04PM 4:22:57PM	Entire Document	Sam W. Francis, American Forest & Paper Association	Return Entire Report	Motion Passed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 303, *Fire Protection Standard for Marinas and Boatyards* A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>303-1</b>	4:39:25PM 4:49:20PM	5.12.3	Kenneth R. Smith, SmartPlug Systems	Accept Proposal 303-7	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 53, Recommended Practice on Materials, Equipment, and Systems Used in Oxygen-Enriched Atmospheres F2009*

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>53-1</b>	4:51:30PM	Title	Marcelo M. Hirschler, GBH International	Accept Comment 53-1	Motion Failed
		Chapter 2	Marcelo M. Hirschler, GBH International	Accept Comment 53-2	
		Chapter 5	Marcelo M. Hirschler, GBH International	Accept Comment 53-3	
		Chapter 6	Marcelo M. Hirschler, GBH International	Accept Comment 53-4	
		Chapter 7	Marcelo M. Hirschler, GBH International	Accept Comment 53-5	
	5:04:37PM	Chapter 8	Marcelo M. Hirschler, GBH International	Accept Comment 53-6	
<b>53-2</b>	5:06:01PM 5:13:08PM	Entire Document	Marcelo M. Hirschler, GBH International	Return Entire Report 53-2	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 86, *Standard for Ovens and Furnaces* A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
86-1	5:14:37PM 5:26:02PM	3.3.17 Flammable Limits, 3.3.17.1 Lower Flammable Limit (LFL), 3.3.17.2 Upper Flammable Limit (UFL)	Marcelo M. Hirschler, GBH International	Accept Comment 86-5	Motion Failed 41-53

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations A2010*

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>96-1</b>	5:27:41PM 5:35:47PM	4.1.5 and A.4.1.5	David A. de Vries, Firetech Engineering Inc.	Accept Comment 96-5	Motion Failed
<b>96-2</b>	NA	11.3.2.1	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Accept Proposal 96-110	Motion not pursued
<b>96-3</b>	NA	11.2.4	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Accept Proposal 96-104	Motion not pursued

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 204, *Standard for Smoke and Heat Venting* A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>204-1</b>	5:38:44PM 6:03:58PM	Chapter 11	Daniel J. O'Connor, Schirmer Engineering Corporation	Reject Comment 204-8	Motion Passed Motion was made to return the document – passed.

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 276, Standard Method of Fire Tests for Determining the Heat Release Rate of Roofing Assemblies with Combustible Above-Deck Roofing Components F2009*

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
276-1	NA	Entire Document	Marcelo M. Hirschler, GBH International	Accept Comment 276-1	Motion not pursued

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems A2010**

<b>Motion Seq #</b>	<b>Time</b>	<b>Section/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
25-1	6:09:25PM	1.1.3.1 and A.1.1.3	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Accept Comment 25-5	Motion 25-1 Failed Motion 25-2 not pursued since it is a Related Motion to 25-1
25-2	6:29:05PM	1.1.3.1 (New)	David A. de Vries, Firetech Engineering Inc.	Accept Comment 25-3	
25-3	6:30:07PM 6:37:59PM	1.1.3.1 (New)	David A. de Vries, Firetech Engineering Inc.	Accept Comment 25-4	Motion Failed
25-4	6:38:34PM 6:54:39PM	3.3.4 Deficiency	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Accept Comment 25-11	Motion Failed
25-5	7:01:24PM 7:09:51PM	3.3.4 Deficiency and A.3.3.4	Marcelo M. Hirschler, GBH International	Accept Comment 25-13	Motion Failed
25-6	7:10:21PM 7:17:04PM	4.1.2.3, 4.1.2.4, and A.4.1.2.3	David A. de Vries, Firetech Engineering Inc.	Accept Comment 25-17	Motion Failed
25-7	7:17:34PM 7:24:07PM	4.1.5 and 4.1.6	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Accept Comment 25-24	Motion Failed
25-8	7:24:31PM 7:29:47PM	4.1.5.1	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Reject Comment 25-21	Motion Failed
25-9	7:30:01PM 7:48:41PM	5.2.1.4	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Reject Comment 25-36	Motion Failed
25-10	7:49:05PM 7:53:40PM	5.2.5	David A. de Vries, Firetech Engineering Inc.	Accept Comment 25-40	Motion Failed
25-11	8:04:30PM 8:16:24PM	5.2.7	Richard M. Ray, Cybor Fire Protection Company	Accept Comment 25-41	Motion Passed
25-12	8:16:48PM 8:25:15PM	7.3.1	Kenneth E. Isman, National Fire Sprinkler Association, Inc.	Accept Comment 25-65	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems A2010 (continued)*

<b>Motion Seq #</b>	<b>Time</b>	<b>Section/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>25-13</b>	8:26:32PM	Table 8.1 and 8.3.1	Richard M. Ray, Cybor Fire Protection Company	Reject Comment 25-68	Motion Failed
		Table 8.1 and 8.3.1	Richard M. Ray, Cybor Fire Protection Company	Reject Comment 25-70	
		Table 8.1 and 8.3.1	Richard M. Ray, Cybor Fire Protection Company	Reject Comment 25-71	
	8:46:41PM	Table 8.1 and 8.3.1	Richard M. Ray, Cybor Fire Protection Company	Reject Comment 25-72	
<b>25-14</b>	8:47:11PM 8:58:15PM	8.3.5	Kenneth E. Isman, National Fire Sprinkler Association, Inc.	Accept Comment 25-75	Motion Failed (40-40)
<b>25-15</b>	9:04:52PM 9:26:32PM	Chapter 14	Russell P. Fleming, National Fire Sprinkler Association, Inc.	Accept Comment 25-104	Motion Passed
<b>25-16</b>	NA	Chapter 14	Terry L. Victor, SimplexGrinnell	Accept an Identifiable Part of Comment 25-104 The acceptance of the identifiable part results in all of Comment 25-104 being accepted except Section 14.2.1.4. <del>14.2.1.4 CPVC Non-metallic pipe shall not be required to be inspected internally.</del>	Motion not pursued
<b>25-17</b>	NA	14.2.1.3 It appears as 14.2.1.4 in Comment 25-104	Richard M. Ray, Cybor Fire Protection Company	Accept Comment 25-110	Motion not pursued
<b>25-18</b>	NA	14.2.1.3, A.14.2.1.3, 14.3.3, and A.14.3.3	Russell B. Leavitt, Telgian Corporation	Accept an Identifiable Part of Comment 25-104	Motion not pursued
<b>25-19</b>	9:29:14PM 9:43:12PM	Chapter 14	Peter A. Larrimer, US Department of Veterans Affairs	Accept Comment 25-101	Motion Passed (45-35)
<b>25-20</b>	NA	Chapter 14	Terry L. Victor, SimplexGrinnell	Accept Comment 25-103	Motion not pursued
<b>25-21</b>	NA	14.2.1.3 It appears as 14.2.1.6 in Comment 25-104	Richard M. Ray, Cybor Fire Protection Company	Accept Comment 25-111	Motion not pursued

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems A2010 (continued)*

<b>Motion Seq #</b>	<b>Time</b>	<b>Section/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
25-22	NA	14.2	Joshua Elvove, U.S. General Services Administration Frable or Larrimer Desig. Rep. for Elvove	Return a portion of a Report in the form of a proposal 25-187 and related comments 25-103, 25-105, 25-106, 25-107, 25-110, and 25-111	Motion not pursued
25-23	NA	14.2.1	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Accept Comment 25-109	Motion not pursued
25-24	NA	A.4.1.5	Joshua Elvove, U.S. General Services Administration Frable and Larrimer are the Desig. Reps*. for Elvove	Accept Comment 25-121	Motion not pursued
25-25	NA	Entire Document	Peter A. Larrimer, US Department of Veterans Affairs  David A. de Vries, Firetech Engineering Inc.	Return Entire Report	Motion not pursued

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 18, *Standard on Wetting Agents* F2009**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>18-1</b>	8:29:04AM	4.5.2.2	Michael T. Greiner, Hazard Control Technologies, Inc.	Reject an Identifiable Part of Comment 18-4. The rejection deletes the following: <b>4.5.2.2</b> The fish toxicity of the wetting agent shall not be less than 10 mg/L when tested in accordance with 4.5.2.2.1.	Motion Failed
	8:47:49AM	5.2.7.2	Michael T. Greiner, Hazard Control Technologies, Inc.	Accept Comment 18-17	

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 58, Liquefied Petroleum Gas Code A2010**

<b>Motion Seq #</b>	<b>Time</b>	<b>Section/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>58-1</b>	8:48:17AM 8:54:43AM	3.3.x Qualified Person	Marcelo M. Hirschler, GBH International	Accept Comment 58-15	Motion Failed
<b>58-2</b>	8:55:23AM 8:59:38AM	3.3.23 Fire Protection	Marcelo M. Hirschler, GBH International	Accept Comment 58-22	Motion Failed
<b>58-3</b>	9:00:05AM 9:05:15AM	3.3.27 Gas	Marcelo M. Hirschler, GBH International	Accept Comment 58-30	Motion Passed
<b>58-4</b>	NA	3.3.27 Gas	Marcelo M. Hirschler, GBH International	Accept an Identifiable Part of Comment 58-30 The acceptance of the identifiable part results in the modification of the definition "Gas" to read as follows: <b>Gas (for the purposes of this code).</b> Liquefied petroleum gas in either the liquid or vapor state.	Motion not pursued
<b>58-5</b>	9:05:58AM 9:23:18AM	4.4	Manuel R. Gomez, US Chemical Safety and Hazard Investigation Board Wanko and Gunaratnam are the Desig. Reps*. for Gomez	Accept Comment 58-49	Motion Passed
<b>58-6</b>	NA	5.2.1.11	Bruce J. Swiecicki, National Propane Gas Association	Reject Comment 58-54	Motion not pursued
<b>58-7</b>	9:29:34AM 9:33:48AM	11.14.1.6 and 11.14.1.7 [11.14.2.2 (New)]	Richard G. Fredenburg, North Carolina Dept. of Agriculture & Consumer Services	Accept Proposal 58-154	Modified Motion Passed to Accept Proposal 58-154, modified to delete the following sentence: "This requirement shall apply to all new installations and to all existing installations within one year of adoption of this code."
<b>58-8</b>	9:34:00AM 9:44:07AM	14.3.2.6 (New)	Richard G. Fredenburg, North Carolina Dept. of Agriculture & Consumer Services	Accept Comment 58-137	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 214, *Standard on Water-Cooling Towers* F2009**

<b>Motion Seq #</b>	<b>Time</b>	<b>Section/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
214-1	9:58:52AM 10:09:57AM	3.3.6 Fire-Resistant Partition	Marcelo M. Hirschler, GBH International	Reject Comment 214-1	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**NFPA 502, Standard for Road Tunnels, Bridges, and Other Limited Access Highways A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>502-1</b>	10:12:27AM 10:24:36AM	7.3.4	Marcelo M. Hirschler, GBH International	Accept Comment 502-23	Motion Failed
<b>502-2</b>	10:25:07AM 10:27:00AM	7.3.4(2)	Marcelo M. Hirschler, GBH International	Reject Comment 502-24	Motion Failed
<b>502-3</b>	10:27:29AM 10:34:37AM	11.1.3.2	Marcelo M. Hirschler, GBH International	Accept Comment 502-32	Motion Failed
<b>502-4</b>	10:35:01AM 10:38:48AM	11.1.3.2	Marcelo M. Hirschler, GBH International	Reject an Identifiable Part of Comment 502-33 The rejection of the identifiable part results in the continued TC deletion of 11.1.3.1 and the rejection of the modification of 11.1.3.2, which would read as follows from Proposal 502-57: <b>11.1.3*</b> Emergency circuits installed in the road tunnel shall meet one of the following methods: (1) A fire resistive cable installed in rigid steel conduit or mineral insulated cable listed for 2-hours in accordance with ANSI/UL 2196 (2) A fire resistant cable listed for 2-hours to other equivalent international standards approved by the AHJ (3) Cables embedded in concrete or protected by a fire barrier shall be listed to maintain functionality at the temperature the cable will be exposed to during the fire event.	Motion Failed
<b>502-5</b>	10:39:09AM 10:47:01AM	11.2.1.3	Marcelo M. Hirschler, GBH International	Accept Comment 502-35	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

NFPA 502, *Standard for Road Tunnels, Bridges, and Other Limited Access Highways* A2010 (continued)

Motion Seq #	Time S	ection/Para	Person(s) Authorized to Make the Motion	Certified Amending Motion**	Floor Action
502-6	10:47:31AM 10:50:11AM	11.2.1.3	Marcelo M. Hirschler, GBH International	Reject an Identifiable Part of Comment 502-35 The rejection of the identifiable part results in the deletion of the following text from the Committee Action in Section 11.2.1.3 as follows: (3) Wires and cables tested to <del>equivalent internationally recognized</del> standards approved by the AHJ. <b>11.2.1.4</b> All cables and conductors used in road tunnels shall emit less than 2% acid gas when tested in accordance with MIL-C 24643 or in accordance with <del>a an</del> <del>equivalent internationally recognized</del> standard approved by the AHJ.	Motion Failed
502-7	10:50:49AM 10:52:55AM	11.2.1.3	Marcelo M. Hirschler, GBH International	Accept Comment 502-36	Motion Failed
502-8	10:53:19AM 10:57:39AM	A.3.3.31	Marcelo M. Hirschler, GBH International	Accept Comment 502-45	Motion Passed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

*NFPA 505, Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Conversions, Maintenance, and Operations F2009*

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
505-1	NA	3.3.4 and 8.7	Lewis C. Barbe, World Safety Organization	Accept Comment 505-1	Motion not pursued

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 1 NFPA 70, *National Electrical Code*® A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
70-1	11:04:27AM 11:11:59AM	110.14(A)	Alan Manche, Square D Company/Schneider Electric	Reject an Identifiable Part of Comment 1-101 The rejection of the identifiable part results in the rejection of the last 5 words of the accepted text in the third paragraph of 110.14(A) in Comment 1-101 as follows: Connectors and terminals for conductors more finely stranded than Class B and Class C stranding as shown in Chapter 9, Table 10 shall be identified for the specific conductor class or classes <del>and the number of strands.</del>	Motion Passed
70-2	11:12:18AM 11:35:51AM	110.24	Alan Manche, Square D Company/Schneider Electric	Return a portion of a Report in the form of a proposal 1-183 and related comments 1-114 through 1-125	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 2 NFPA 70, *National Electrical Code*® A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
70-3	11:36:30AM 11:54:03AM	210.19(A)(5) (New)	Paul A. Keleher, Paul Keleher Electrical Services	Accept an Identifiable Part of Proposal 2-193 The acceptance of the identifiable part results in accepting the following new text: <b>210.19(A) Branch Circuits Not More Than 600 Volts.</b> <b>(5) Permissible Voltage Drop.</b> The circuit conductors of a 15 or 20-ampere/120-volt branch circuit shall be sized such that voltage-drop measured at the rated ampacity of the circuit shall be 5% or less at any outlet.	Motion Failed (94-125)

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 3 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
70-4	11:54:34AM 12:08:32PM	300.4(G)	Carlo Compagnone, Jr., Compa Covers, Inc. Tomasino is the Desig. Rep.* for Compagnone	Accept Comment 3-13	Motion Failed
70-5	12:08:59:PM 12:16:01PM	300.6(A)	Martin J. Brett, Jr., Newark, NJ	Reject Comment 3-22	Motion Passed
70-6	12:34:12PM 1:04:50PM	590.6	Michael O. Flegel, Racine, WI	Accept Comment 3-69	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 6 NFPA 70, *National Electrical Code*® A2010**

<b>Motion Seq #</b>	<b>Time</b>	<b>Section/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
70-7	1:05:10PM	310.15(B)(2)(c) and FPN, and Table 310.15(B)(2)(c) and FPN	Christel K. Hunter, Alcan Cable	Accept Comment 6-43	Motion 70-7 Failed Motion 70-8 not pursued since it is a Related Motion to 70-7
70-8	1:28:50PM	310.15(B)(2)(c) and Table 310.15(B)(2)(c)	Martin J. Brett, Jr., Newark, NJ	Accept Comment 6-44	
70-9	NA	310.15(B)(2)(c)	Elaine Thompson, Steel Tube Institute of North America Thompson is the Desig. Rep.* for Wolfe.	Accept Comment 6-35	Motion not pursued
70-10	1:29:52PM 1:38:41PM	310.15(B)(6), (2008 edition) 310.15(B)(7) (ROP Draft)	Richard A. Holub, Middletown, DE Holub is the Desig. Rep*. for Cline	Accept an Identifiable Part as modified by Panel for Comment 6-55 The acceptance of the identifiable part results in the acceptance of the Comment 6-55 as modified by the Panel, with the omission of the word "corrected" in the last sentence of 310.15(B)(7)(b).	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 7 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>70-11</b>	1:39:23PM 1:48:50PM	334.15(C)	Gerald H. Horn, Spencer Research & Development	Accept Comment 7-34	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 9 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
70-12	1:49:32PM 1:56:00PM	314.17(E)	Carlo Compagnone, Jr., Compa Covers, Inc. Tomasino is the Desig. Rep.* for Compagnone	Accept comment 9-26	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 10 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>70-13</b>	1:56:58PM 2:07:30PM	240.87	Alan Manche, Square D Company/Schneider Electric	Return a portion of a Report in the form of a proposal 10-82 and related comments 10-35 through 10-44	Motion Failed
<b>70-14</b>	2:07:50PM 2:29:37PM	240.4 FPN	Ed Larsen, Schneider Electric	Reject Comment 10-7	Motion Failed
<b>70-15</b>	2:45:13PM 2:52:40PM	240.91	Chad Kennedy, Schneider Electric/Square D	Accept Comment 10-47	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 11 NFPA 70, *National Electrical Code*® A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
70-16	2:53:40PM 3:03:14PM	430.123	Jay Tamblingson, Rockwell Automation  Lori L. Tennant, Schneider Electric	Return a portion of a Report in the form of a proposal 11-107a and related comment 11-43a,11-44, 11-45, 11-46, and 11-47	Motion Passed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 13 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
70-17	3:03:50PM 3:12:37PM	695.4(B)(3)	Daniel J. Caron, Bard, Rao + Athanas Consulting Engineers, LLC	Accept as Modified by Panel for Comment 13-96	Motion Passed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 14 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>70-18</b>	NA	505.4(B) FPN No. 7	David B. Wechsler Rep. American Chemistry Council	Accept Comment 14-88a	Motion not pursued
<b>70-19</b>	3:14:17PM 3:22:08PM	505.9(C)(2) FPN	Michael P. Walls, American Chemistry Council	Accept Comment 14-92	Motion Failed

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 15 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time S</b>	<b>ection/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>70-20</b>	3:23:24PM 3:42:29PM	517.30(C)(3)	William W. Wolfe, Steel Tube Institute of North America Horton is the Desig. Rep.* for Wolfe	Reject Comment 15-101	Motion 70-20 Passed Motion 70-21 was not pursued since it was a Multiple Notice for a Single Motion to 70-20
<b>70-21</b>			Stephen M. Lipster, The Electrical Trades Center		

**Floor Action on Certified Amending Motions  
Documents for the June 2010 Association Technical Meeting**

**Panel 17 NFPA 70, *National Electrical Code*<sup>®</sup> A2010**

<b>Motion Seq #</b>	<b>Time</b>	<b>Section/Para</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Certified Amending Motion**</b>	<b>Floor Action</b>
<b>70-22</b>	3:43:50PM 3:55:43PM	680.26(B)(2)(b)	Wayne H. Robinson, Lothian, MD	Accept Comment 17-86	Motion Passed