



Errata

## NFPA 55

### Compressed Gases and Cryogenic Fluids Code

2010 Edition

**Reference:** 7.1.17.7

**Errata No.:** 55-10-2

The Committee on Industrial and Medical Gases notes the following error in the 2010 edition of NFPA 55, *Compressed Gases and Cryogenic Fluids Code*.

1. *Revise 7.1.17.7 to read as follows:*

**7.1.17.7** In areas not subject to vehicle traffic, the pipe trench shall be deep enough to permit a cover of at least ~~6~~ 12 in. (~~150~~ 300 mm) of well-compacted backfill material. [~~30:27.6.5.5~~]

**Issue Date:** January 11, 2010

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see [www.nfpa.org/codelist](http://www.nfpa.org/codelist))

Copyright © 2010 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION