

Formal Interpretation

NFPA 110

Emergency and Standby Power Systems

2005 Edition

Reference: 8.4.9

F.I. 05-1 (NFPA 110)

Question 1: Is it the intent of 8.4.9 to require a Level 1 EPSS to be tested for less than 4 hours if the class is designated as less than class 4?

Answer: Yes.

Question 2: Is it the intent of 8.4.9 to require a Level 1 EPSS to be tested for a duration of more than 4 hours when the class is designated as more than class 4?

Answer: No.

Issue Edition: 2005

Reference: 8.4.9

Issue Date: November 29, 2006

Effective Date: December 18, 2006