

Formal Interpretation

NFPA 17

Dry Chemical Extinguishing Systems

2009 Edition

Reference: 9.6.1

F.I. 02-1 (NFPA 17)

Question: Is it the intent of NFPA 17, 2002 edition, section 9.6.1 that the suppression system shall have two sources of power (main and reserve) for automatic and manual actuation?

Answer: Yes.

Issue Edition: 2002

Reference: 9.6.1

Issue Date: August 21, 2003

Effective Date: September 11, 2003