

Formal Interpretation

NFPA 24

Standard for the Installation of Private Fire Service Mains and Their Appurtenances

2010 Edition

Reference: 10.1.1

F.I. No.: 24-07-01

Question No. 1: Is it acceptable to use underground pipe that is not referenced in Table 10.1.1, but is specifically listed for Fire protection Service and complies with the applicable AWWA standards for the pipe?

Answer: Yes

Issue Edition: 2007

Reference: 10.1.1

Issue Date: 01/25/2007

Effective Date: 2/14/2007