

Formal Interpretation

# NFPA 318

## Protection of Cleanrooms

2009 Edition

**Reference:** 7.2.9

**F.I. 92-1**

**Question:** Is double-walled piping intended to be the only method of secondary containment of piping systems?

**Answer:** No.

**Issue Edition:** 1992

**Reference:** 5-2.7

**Issue Date:** August 3, 1992

**Effective Date:** August 24, 1992

Copyright © 2008 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION