

Formal Interpretation

# NFPA 423

## Construction and Protection of Aircraft Engine Test Facilities

2004 Edition

**Reference: 7.6.3**

**F.I. 89-1 (NFPA 423)**

**Question 1:** For automatic sprinkler system protection for an engine test cell, is the “protected area” the entire floor area?

**Answer:** Yes.

**Question 2:** For water deluge system protection for an engine test cell, is the “protected area” the entire floor area?

**Answer:** Yes.

**Issue Edition: 1989**

**Reference: 5-6.3**

**Issue Date: April 18, 1994**

**Effective Date: May 8, 1994**