

Formal Interpretation

NFPA 59

Liquefied Petroleum Gases at Utility Gas Plants

2008 Edition

Reference: 5.5.2.10(B)

F.I. 84-1

Question: Is it the intent of 5.5.2.10(B) that permanently plugged bottom openings to which nothing can be connected be considered as “bottom connections to the container”?

Answer: Yes.

Issue Edition: 1984

Reference: 2-5.3.5

Date: September 1985

Copyright © 2008 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION