

Formal Interpretation

NFPA 664

Prevention of Fires and Explosions in Wood Processing and Woodworking Facilities

2007 Edition

Reference: 8.6.5

F.I. 664-02-1

Question: Did the 664 Technical Committee intend to encompass wood heating units not intended to reduce moisture content nor resulting in reduced moisture content below that of "green material" (25% or more) within the scope of the requirements of Subsection 8.6.5 Kiln Dryers?

Answer: No.

Issue Edition: 2002

Reference: 8.6.5

Date: February 16, 2006

Effective Date: March 8, 2006

Copyright © 2006 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION