

Formal Interpretation

NFPA 820

Fire Protection in Wastewater Treatment and Collection Facilities

2008 Edition

Reference: Tables 4.2, 5.2, and 6.2

F.I. 92-1

Background: In Tables 4.2, 5.2, and 6.2(a), footnote code A is defined as “Ventilated at less than 12 air changes per hour.”

Question 1: Does this definition include mechanically ventilated at any rate less than 12 air changes per hour (including 1 air change per hour or less)?

Answer: Yes.

Question 2: Does this definition include ventilated with a static vent (without mechanical ventilation)?

Answer: Yes.

Issue Edition: 1992

Reference: Tables 2, 3, 4, and 5

Issue Date: May 11, 1992

Effective Date: June 1, 1992