



Tentative Interim Amendment

# NFPA 11

## Standard for Low-, Medium-, and High-Expansion Foam

2005 Edition

**Reference: 4.7.3.4**

**TIA 05-2**

*(SC 07-10-9/TIA Log #889)*

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 11, *Standard for Low-, Medium-, and High-Expansion Foam*, 2005 edition. The TIA was processed by the Technical Committee on Foam, and was issued by the Standards Council on October 4, 2007, with an effective date of October 24, 2007.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

*1. Revise 4.7.3.4 to read as follows:*

**4.7.3.4** Rubber or elastomeric-gasketed fittings shall not be used in fire-exposed ~~areas~~ hazards unless the foam system is automatically actuated, or test data is submitted to show acceptable performance under fire conditions within a fire exposed hazard.

**Issue Date:** October 4, 2007

**Effective Date:** October 24, 2007