



Tentative Interim Amendment

# NFPA 54

## National Fuel Gas Code

2009 Edition

**Reference: 12.2.4**

**TIA 09-1**

*(SC 08-7-19/TIA Log #918)*

**Note:** Text of the TIA issued and incorporated into the text of 12.2.4 and therefore no separate publication is necessary.

*1. Delete proposed new paragraph 12.2.4 as recommended by Proposal 54-74 in the 2008 Annual Revision Cycle Report on Proposals. The proposed text which is recommended for deletion by this TIA reads as follows:*

**12.2.4** Appliance vents shall not discharge into any space enclosed by insect screens having openings smaller than  $\frac{1}{4}$  inch mesh.