



Tentative Interim Amendment

NFPA 59

Utility LP-Gas Plant Code

2008 Edition

Reference: 5.4.1.2 and 5.4.2.4(4)

TIA 08-1

(SC 09-8-15/TIA Log #963)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 59, *Utility LP-Gas Plant Code*, 2008 edition. The TIA was processed by the Technical Committee on LP-Gases at Utility Gas Plants, and was issued by the Standards Council on August 6, 2009, with an effective date of August 26, 2009.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Revise 5.4.1.2 to read as follows:

5.4.1.2 Containers larger than 2,000 gal (7.6 m³) water capacity shall be located in accordance with Table 5.4.1.2 with respect to the distance between containers, the distance between containers and the nearest important building or group of buildings not associated with the utility gas plant, or a line of adjoining property that can be built upon. Containers of 2,000 gal (7.6 m³) water capacity and less shall be located in accordance with NFPA 58, *Liquefied Petroleum Gas Code*, Table 6.3.1.

2. Add a new subsection 5.4.2.4(4) to read:

5.4.2.4 (4) Underground containers of 2,000 gal ((7.6 m³) and less shall be located in accordance with NFPA 58, *Liquefied Petroleum Gas Code*, Table 6.3.1.

Issue Date: August 6, 2009

Effective Date: August 26, 2009

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/codelist)