



Tentative Interim Amendment

NFPA 72[®]

National Fire Alarm and Signaling Code

2010 Edition

Reference: 17.4.9 and 17.7.5.5.8

TIA 10-2

(SC 09-8-19/TIA Log #964)

Note: Text of the TIA issued and incorporated into the text of 17.4.9 and 17.7.5.5.8 therefore no separate publication is necessary.

1. Add 17.4.9 to read as follows:

17.4.9 Where required by 17.4.8 and unless the specific detector alarm or supervisory signal is indicated at the control unit, remote alarm or supervisory indicators shall be installed in an accessible location and shall be clearly labeled to indicate both their function and the air-handling unit(s) associated with each detector.

2. Delete 17.7.5.5.8.

Issue Date: August 6, 2009

Effective Date: August 26, 2009

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/codelist)