



Tentative Interim Amendment

NFPA 86

Standard for Ovens and Furnaces

2007 Edition

Reference: 8.2.9

TIA 07-1

(SC 09-03-7/TIA Log #940)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 86, *Standard for Ovens and Furnaces*, 2007 edition. The TIA was processed by the Technical Committee on Ovens and Furnaces, and was issued by the Standards Council on March 4, 2009, with an effective date of March 24, 2009.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Add a new subsection 8.2.9 to read as follows:

8.2.9 Shutdown of the heating system by any safety feature or safety device shall require manual intervention of an operator for re-establishment of the normal operation of the system.

Issue Date: March 4, 2009

Effective Date: March 24, 2009

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/codelist)