

**CONSOLIDATED REPORT OF THE MOTIONS COMMITTEE**  
**ON CERTIFIED AMENDING MOTIONS**  
**FOR PRESENTATION AT THE**  
**2007 ASSOCIATION TECHNICAL MEETING,**  
**JUNE 6-7, 2007, BOSTON, MASSACHUSETTS**

**I. Introduction.** This is the Consolidated Final Motions Committee Report (Consolidated Report) listing Certified Amending Motions that may be presented at the 2007 Association Technical Meeting in Boston, MA on June 6-7, 2007. The Motions Committee, consisting of NFPA Standards Council Members P. DiNenno (Chair), S. Clary, M. Newman, J. Pauley and P. Willse, has been appointed by the Chair of the Standards Council to certify proper amending motions and otherwise review and act, in accordance with 2.1 through 2.5 of the *NFPA Technical Meeting Convention Rules (Convention Rules)*, on Notices of Intent to Make a Motion (NITMAMs) that have been submitted on NFPA codes and standards (Documents), which are being processed in the Fall 2006 Revision Cycle and the Annual 2007 Revision Cycle [including NFPA 70, *National Electrical Code*<sup>®</sup> (NEC<sup>®</sup>)].

This Consolidated Report consolidates the three previous Motions Committee Reports related to the 2007 Association Technical Meeting, namely: the Report for the NEC (posted May 18, 2007); the Report for Annual 2007 Revision Cycle non-NEC Documents (posted May 2, 2007); and the Report for the Fall 2006 Revision Cycle Documents (posted November 15, 2006). The Consolidated Report contains all of the certified amending motions contained in the three base Reports. However, the Motions Committee may have refined or revised the sequencing and/or grouping of previously published motions to facilitate the fair, orderly and efficient consideration of the subjects presented by the motions at the Association Meeting.

Under NFPA rules, persons wishing to make an allowable amending motion at an NFPA Technical Meeting must declare their intention to do so by filing, within the published deadlines, a NITMAM setting forth information about the intended motion. The Motions Committee, in accordance with NFPA rules, reviews each NITMAM to determine whether the intended motion is a proper motion. The Committee can also, in consultation with the submitter of the NITMAM, clarify the intent of, and, if appropriate, restate the motion, and, in certain circumstances, group together motions that are dependent on each other so that they can be made as a single motion. In addition, the Motions Committee may take such other action or make such other recommendations as will facilitate the fair, orderly and efficient consideration of motions within the available time. The Motions Committee certifies for presentation at the appropriate Association Technical Meeting all proper Amending Motions, either as submitted or as clarified, restated or grouped, as explained above. The Motions Committee then publishes a report setting forth, at a minimum, each Certified Amending Motion, the person(s) authorized to make such motions, and the recommended order in which motions should be entertained. In addition, the Report may include Motions Committee notes or comments aimed at assisting the Presiding Officer or facilitating the understanding of or the orderly and efficient consideration of the motion when presented at the Association Technical Meeting.

The Certified Amending Motions for documents in the Fall 2006 Revision Cycle, and documents (including the NEC) in the Annual 2007 Revision Cycle Documents are set forth in Part II of this report. Part III summarizes NITMAM's for those documents in the cycles identified above that were

not certified by the Motions Committee. In reviewing this report, the following should be considered:

- The only Amending Motions allowed at an Association Technical Meeting are Certified Amending Motions set forth in a report of the Motions Committee and any Follow-Up Motions, that is, motions that may become necessary as a result of a previous successful Amending Motion. (See *Convention Rules* at 3.4.4.)
- Certified Amending Motions can only be made by person(s) listed in this Report as authorized to make the motion, or by persons they have designated in writing to the Standards Council Secretary as their Designated Representative. See *Regulations Governing Committee Projects (Regulations)* at 4.6.8.1. (Note, in the case of Organization Members as defined in Section 3.5 of the *NFPA Bylaws*, the Organization Member Delegate is also a permissible maker of the motion. See *Regulations* at 4.6.8.2.)
- The Certified Amending Motions set forth in this report are proper and permissible; they will, however, only be presented for the consideration of the membership at the 2007 Association Technical Meeting if a person authorized to make the motion (or their Designated Representative or, in the case of an Organization Member, the Organization Member Delegate) actually appears, signs in no later than one hour before the beginning of the session (see *Convention Rules* at 2.7), and makes the motion in accordance with NFPA rules.
- This Report concerns all Certified Amending Motions for consideration at the 2007 Association Technical Meeting in Boston, MA on June 6-7, 2007.

The information presented above provides a general introduction to some of the relevant features of the NITMAM process and the presentation of Certified Amending Motions. For a full and complete understanding of the process, participants should consult the rules themselves, including the *Convention Rules* and the *Regulations*. In particular, the rules concerning the submission of NITMAMS and the Certification of Amending Motions can be found at 2.0 of the *Convention Rules* and 4.5 of the *Regulations*. The rules concerning membership action at Association Technical Meetings can be found, generally, in the *Convention Rules* and in 4.6 of the *Regulations*. These are published in the 2007 Annual Directory and are available on the NFPA website at [www.nfpa.org](http://www.nfpa.org). For additional information about the NFPA codes and standards process, consult the NFPA website or contact NFPA Codes & Standards Administration Department at 617-984-7245.

**II. Certified Amending Motions.** Previously, the Motions Committee had ruled that six Annual 2007 Revision Cycle Documents (including the NEC) and four Fall 2006 Revision Cycle Documents had certified amending motions for consideration at the 2007 Association Technical Meeting (see the previously published reports as noted above). These rulings have not been modified. The consolidated list of documents with certified amending motions is as follows:

NFPA 12, *Standard on Carbon Dioxide Extinguishing Systems*

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*

NFPA 30, *Flammable and Combustible Liquids Code*

NFPA 58, *Liquefied Petroleum Gas Code*

NFPA 70, *National Electrical Code*

NFPA 96, *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*  
NFPA 301, *Code for Safety to Life from Fire on Merchant Vessels*  
NFPA 415, *Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways*  
NFPA 780, *Standard for the Installation of Lightning Protection Systems*  
NFPA 2001, *Standard on Clean Agent Fire Extinguishing Systems*

Table IIA summarizes the motions that have been reviewed and certified by the Motions Committee for documents processed in the Annual 2007 revision cycle (except NFPA 70), and in the Fall 2006 revision cycle. Table IIB summarizes the motions that have been reviewed and certified by the Motions Committee for NFPA 70. (There is no Table I to this report).

### **III. NITMAMs that were not Certified by Motions Committee.**

Table IIIA summarizes the NITMAMs for documents processed in the Annual 2007 revision cycle, with the exception of NFPA 70, and in the Fall 2006 revision cycle that have been reviewed by the Motions Committee and not certified. (Note that Table IIIA only includes documents in the Fall 2006 revision cycle as no NITMAM's for documents in the Annual 2007 revision cycle, with the exception of NFPA 70, were not certified.) Table IIIB summarizes the NITMAMs for NFPA 70 that have been reviewed by the Motions Committee and not certified.

### **IV. Consent Documents.**

Where a Document in the Annual 2007 Revisions Cycle or the Fall 2006 Revision Cycle receives no NITMAMs, or receives NITMAM's but none are certified by the Motions Committee as Certified Amending Motions, the Document is considered a "Consent Document." A Consent Document is not presented to the Association Technical Meeting and is, instead, forwarded directly to the Standards Council for issuance. See *Regulations* at 4.5.6.

As previously reported, following are the twenty-two Consent Documents in the Annual 2007 Revision Cycle that will be forwarded directly to the Standards Council for issuance at its meeting scheduled for June 4, 2007:

NFPA 30A, *Code for Motor Fuel Dispensing Facilities and Repair Garages*  
NFPA 61, *Standard for the Prevention of Fires and Dust Explosions in Agricultural and Food Processing Facilities*  
NFPA 69, *Standard on Explosion Prevention Systems*  
NFPA 252, *Standard Methods of Fire Tests of Door Assemblies*  
NFPA 259, *Standard Test Method for Potential Heat of Building Materials*  
NFPA 270, *Standard Test Method for Measurement of Smoke Obscuration Using a Conical Radiant Source in a Single Closed Chamber*  
NFPA 272, *Standard Method of Test for Heat and Visible Smoke Release Rates for Upholstered Furniture Components or Composites and Mattresses Using an Oxygen Consumption Calorimeter (withdrawn)*  
NFPA 402, *Guide for Aircraft Rescue and Fire Fighting Operations*  
NFPA 424, *Guide for Airport/Community Emergency Planning*  
NFPA 471, *Recommended Practice for Responding to Hazardous Materials Incidents (withdrawn)*  
NFPA 472, *Standard for Competence of Responders to Hazardous Materials/Weapons of Mass Destruction Incidents*

NFPA 473, *Standard for Competencies for EMS Personnel Responding to Hazardous Material/Weapons of Mass Destruction Incidents*  
 NFPA 502, *Standard for Road Tunnels, Bridges, and Other Limited Access Highways*  
 NFPA 820, *Standard for Fire Protection in Wastewater Treatment and Collection Facilities*  
 NFPA 1001, *Standard for Fire Fighter Professional Qualifications*  
 NFPA 1122, *Code for Model Rocketry*  
 NFPA 1127, *Code for High Power Rocketry*  
 NFPA 1141, *Standard for Fire Protection Infrastructure for Land Development in Suburban and Rural Areas*  
 NFPA 1144, *Standard for Reducing Structure Ignition Hazards from Wildland Fire*  
 NFPA 1521, *Standard for Fire Department Safety Officer*  
 NFPA 1583, *Standard on Health-Related Fitness Programs for Fire Department Members*  
 NFPA 1851, *Standard on Selection, Care, and Maintenance of Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting*

Following are the twenty-seven Consent Documents in the Fall 2006 Revision Cycle that were previously acted on and issued by the Standards Council.

NFPA 16, *Standard for the Installation of Foam-Water Sprinkler and Foam-Water Spray Systems*  
 NFPA 18A, *Standard on Water Additives for Fire Control and Vapor Mitigation*  
 NFPA 51, *Standard for the Design and Installation of Oxygen–Fuel Gas Systems for Welding, Cutting, and Allied Processes*  
 NFPA 68, *Standard on Explosion Protection by Deflagration Venting*  
 NFPA 85, *Boiler and Combustion Systems Hazards Code*  
 NFPA 204, *Standard for Smoke and Heat Venting*  
 NFPA 385, *Standard for Tank Vehicles for Flammable and Combustible Liquids*  
 NFPA 550, *Guide to the Fire Safety Concepts Tree*  
 NFPA 551, *Guide for the Evaluation of Fire Risk Assessments*  
 NFPA 560, *Standard for the Storage, Handling, and Use of Ethylene Oxide for Sterilization and Fumigation*  
 NFPA 900, *Building Energy Code*  
 NFPA 1005, *Standard for Professional Qualifications for Marine Fire Fighting for Land-Based Fire Fighters*  
 NFPA 1037, *Standard for Professional Qualifications for Fire Marshal*  
 NFPA 1041, *Standard for Fire Service Instructor Professional Qualifications*  
 NFPA 1051, *Standard for Wildland Fire Fighter Professional Qualifications*  
 NFPA 1061, *Standard for Professional Qualifications for Public Safety Telecommunicator*  
 NFPA 1402, *Guide to Building Fire Service Training Centers*  
 NFPA 1403, *Standard on Live Fire Training Evolutions*  
 NFPA 1451, *Standard for a Fire Service Vehicle Operations Training Program*  
 NFPA 1600, *Standard on Disaster/Emergency Management and Business Continuity Programs*  
 NFPA 1911, *Standard for the Inspection, Maintenance, Testing, and Retirement of In-Service Automotive Fire Apparatus*  
 NFPA 1914, *Standard for Testing Fire Department Aerial Devices*  
 NFPA 1915, *Standard for Fire Apparatus Preventive Maintenance Program*  
 NFPA 1951, *Standard on Protective Ensembles for Technical Rescue Incidents*  
 NFPA 1961, *Standard on Fire Hose*  
 NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus (SCBA) for Emergency Services*  
 NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Item # 1 NFPA 415 Airport Facilities**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
415	1	A2007	4.5.1.1	Jon Nisja, Northcentral Regional Fire Code Development Committee	00307	Accept Comment 415-1	
415	2	A2007	4.5.5.1	Jon Nisja, Northcentral Regional Fire Code Development Committee	00308	Accept Comment 415-3	

**Item # 2 NFPA 30 Flammable and Combustible Liquids Flammable and Combustible Liquids**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
30	1	F2006	4.3.2.3.3 (22.10.3)	Rick Thornberry, The Code Consortium, Inc.	00279	Accept Comment 30-15	
30	2	F2006	22.10.3	Rick Thornberry, The Code Consortium, Inc.	00278	Reject Comment 30-45	

**Item # 3 NFPA 12 Gaseous Fire Extinguishing Systems**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
12	1	F2006	4.1	Thomas J. Wysocki, Guardian Services, Inc.	00281	Accept Comment 12-1	

Date Printed 5/29/2007

\*Designated Representative in accordance with 4.6.8.1 and /or 4.6.8.2 of NFPA's Regulation Governing Committee projects

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Item # 4 NFPA 2001 Gaseous Fire Extinguishing Systems**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
2001	1	A2007	5.4.2.5, 5.4.2.5.1, 5.4.2.5.2, 5.4.2.5.3, 5.4.2.5.4, and A.5.4.2.5.2	Mark L. Robin, DuPont Fluoroproducts Dale R. Edlbeck, Ansul Incorporated (Log #293). Ronald Marts, Affiliation Telecordia (Log #294).	00285 00293 00294	Reject Comment 2001-61a	Multiple Notices for a Single Motion (to reject comment 2001-61a) per section 2.4 of NFPA's Convention Rules.
2001	2	A2007	5.4.2.5, 5.4.2.5.1, 5.4.2.5.2, 5.4.2.5.3, 5.4.2.5.4, and A.5.4.2.5.2	Brad T. Stilwell, Fike Corporation	00288	Return a portion of a Report in the form of a proposal and related comment(s) 2001-61a	

**Item # 5 NFPA 25 Inspection, Testing, and Maintenance of Water-Based Systems**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
25	1	F2006	4.1.5, 4.1.5.1, 4.1.5.2, 4.1.6, 4.1.6.1 and 4.1.6.2	Joshua Elvove, US General Services Administration D. Frable is the Desig. Rep* for Elvove.	00235	Accept an Identifiable Part Comment 25-12  The Identifiable Part is: Accept Proposal 25-26.	
25	2	F2006	4.1.5, 4.1.5.1, 4.1.5.2, 4.1.6, 4.1.6.1 and 4.1.6.2	Joshua Elvove, US General Services Administration D. Frable is the Desig. Rep* for Elvove.	00284	Accept an Identifiable Part Comment 25-12  The Identifiable Part is: Reject Proposal 25-28.	Certified Amending Motion, only if Log # 235 is not successful.
25	3	F2006	4.1.8	Joshua Elvove, US General Services Administration D. Frable is the Desig. Rep* for Elvove.	00236	Accept Comment 25-13	
25	4	F2006	5.3.2.1 and 5.3.2.2	Frank L. Van Overmeiren, FP&C Consultants, Inc.	00282	Accept Comment 25-31	

Date Printed 5/29/2007

\*Designated Representative in accordance with 4.6.8.1 and /or 4.6.8.2 of NFPA's Regulation Governing Committee projects

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

25	5	F2006	12.7.1	Joshua Elvove, US General Services Administration D. Frable is the Desig. Rep* for Elvove.	00237	Accept Comment 25-61
25	6	F2006	13.2	Joshua Elvove, US General Services Administration D. Frable is the Desig. Rep* for Elvove.	00238	Accept Comment 25-64

**Item # 6 NFPA 780 Lightning Protection**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
780	1	A2007	Annex B	William Heary, Heary Brothers Lightning Protection Co. Inc.	00314	Return a portion of a Report in the form on identifiable part(s) of a proposal and related comment(s) 780-38	
The portion of the report to be returned is: Entire Annex B							

**Item # 7 NFPA 58 Liquefied Petroleum Gases**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
58	1	F2006	6.17	Jon Nisja, IFMA S. Adams is the Desig. Rep* for Nisja.	00226	Accept Comment 58-93	
58	2	F2006	6.17	Thomas A. Wilson, City of Winter Park	00264	Accept Comment 58-94	

See Note.

**Related Motions:** Motions 58-1 and 58-2 (logs 226 and 264), while different in the means they employ, seek to achieve the same action. Specifically, any one of the two motions, if successful would delete proposed new provisions on composite cylinders used with listed cabinet heaters inside of buildings. Both motions have been certified as proper. So as to eliminate multiple debates on the same proposed action, however, the following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once either of the motions is made and seconded, the other will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

58	3	F2006	5.18.8	Jon Nisja, IFMA S. Adams is the Desig. Rep* for Nisja.	00227	Accept Comment 58-68	<p><b>Related Motions:</b> Motions 58-3 and 58-4 (logs 227 and 258), while different in the means they employ, seek to achieve the same action. Specifically, any one of the two motions, if successful would delete proposed new text on composite cylinders and cabinet heaters. Both motions have been certified as proper. So as to eliminate multiple debates on the same proposed action, however, the following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once either of the motions is made and seconded, the other will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.</p>
58	4	F2006	5.7.6.4, 5.6.6.5, 5.18.8, A.5.7.6.5	Thomas A. Wilson, City of Winter Park	00258	Accept Comment 58-53	



**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

58	5	F2006	5.18.8	Phani K. Raj, Technology & Management Systems, Inc.	00233	Accept as Modified by TC Comment 58-69
----	---	-------	--------	---	-------	--

58	6	F2006	7.4.3.3	Bill Mahre, Propane Technical Services	00240	Accept Comment 58-115
----	---	-------	---------	--	-------	-----------------------

58	7	F2006	7.4.3.3	Thomas A. Wilson, City of Winter Park	00270	Accept Comment 58-116
----	---	-------	---------	---------------------------------------	-------	-----------------------

**Related Motions:** Motions 58-6 and 58-7 (logs 240 and 270), while different in the means they employ, seek to achieve the same action. Specifically, any one of the two motions, if successful would delete proposed new text on filling levels for composite cylinders. Both motions have been certified as proper. So as to eliminate multiple debates on the same proposed action, however, the following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once either of the motions is made and seconded, the other will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

58	8	F2006	7.4.2.2	Bill Mahre, Propane Technical Services	00239	Accept Comment 58-112
58	9	F2006	A.7.4.1.3.2(A)	Jon Nisja, IFMA S. Adams is the Desig. Rep* for Nisja.	00228	Accept Comment 58-155
58	10	F2006	A.7.4.3.2(A)	Thomas A. Wilson, City of Winter Park	00273	Accept Comment 58-156

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

58	11	F2006	5.2.1.1	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00251	Accept Comment 58-31	<p><b>Group Amending Motion (58-11).</b>                  Motions identified by log numbers 251, 252, 253, 254, 256, 257, 262, 268, 269, and 271 taken together seek to prohibit, in various sections of the code, the use of propane heaters within residential occupancies. The motions themselves should be consulted for a description of the precise action sought. All ten motions have been certified as proper. In addition, with the agreement of the authorized maker of the motions, these motions are being considered as dependent motions which will be debated and voted on by the assembly as a single up or down package. See NFPA Technical Meeting Convention Rules 2.3. Accordingly, the following procedure will be in effect for these motions at the Technical Session: the ten dependent motions will be grouped into a single "Group Amending Motion" identified as Motion 58-11 which, once made by the authorized person, will effectively place all ten dependent motions on the floor for debate and vote as a single up or down motion.</p>
58		F2006	5.2.1.2	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00252	Accept Comment 58-34	
58		F2006	5.2.3.2	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00253	Accept Comment 58-35	
58		F2006	5.7.2.3	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00254	Accept Comment 58-43	
58		F2006	5.7.6	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00256	Accept Comment 58-49	
58		F2006	5.7.6	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00257	Accept Comment 58-50	
58		F2006	6.17	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00262	Accept Comment 58-92	
58		F2006	7.4.2	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00268	Accept Comment 58-111	
58		F2006	7.4.3.2(A)	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00269	Accept Comment 58-113	
58		F2006	11.3	Thomas A. Wilson, City of Winter Park	00271	Accept Comment 58-126	

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

58	12	F2006	A.7.4.3.2(A)	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00272	Accept Comment 58-154	<p><b>Group Amending Motion (58-12).</b>                  Motions identified by log numbers 272 and 276 taken together seek to add advisory text in two separate code sections on prohibiting the use of propane heaters within residential occupancies. The motions themselves should be consulted for a description of the precise action sought. Both motions have been certified as proper. In addition, with the agreement of the authorized maker of the motions, these motions are being considered as dependent motions which will be debated and voted on by the assembly as a single up or down package. See NFPA Technical Meeting Convention Rules 2.3. Accordingly, the following procedure will be in effect for these motions at the Technical Session: the two dependent motions will be grouped into a single "Group Amending Motion" identified as Motion 58-12 which, once made by the authorized person, will effectively place both dependent motions on the floor for debate and vote as a single up or down motion.</p>
58		F2006	C.3.2.2.1	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00276	Accept Comment 58-160	

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

58	13	F2006	3.3.11 and 3.3.17.2	Thomas A. Wilson, City of Winter Park	00249	Accept Comment 58-7	<p><b>Related Motions:</b> Motions 58-13 and 58-14 (logs 249 and 229), while different in the means they employ, seek to achieve the same action. Specifically, any one of the two motions, if successful would delete proposed new definition of cabinet heater. Both motions have been certified as proper. So as to eliminate multiple debates on the same proposed action, however, the following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once either of the motions is made and seconded, the other will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.</p>
58	14	F2006	3.3.11	Jon Nisja, IFMA S. Adams is the Desig. Rep* for Nisja.	00229	Accept Comment 58-1	

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

58	15	F2006	3.3.11 and 3.3.17.2	Thomas A. Wilson, City of Winter Park Hayes is the Desig. Rep* for Wilson.	00250	Accept Comment 58-8
58	16	F2006	3.3.11	Thomas A. Wilson, City of Winter Park	00243	Reject Comment 58-2
58	17	F2006	5.15.1.3	Phani K. Raj, Technology & Management Systems, Inc.	00232	Accept Comment 58-66
58	18	F2006	5.3	Bruce J. Swiecicki, National Propane Gas Association	00241	Accept Comment 58-39
58	19	F2006	5.7.2.3	Thomas A. Wilson, City of Winter Park	00255	Reject Comment 58-44
58	20	F2006	Table 5.7.6.2	Phani K. Raj, Technology & Management Systems, Inc.	00230	Accept Comment 58-51
58	21	F2006	Table 5.7.7.1	Phani K. Raj, Technology & Management Systems, Inc.	00231	Accept as Modified by TC Comment 58-58
58	22	F2006	6.25.1	Phani K. Raj, Technology & Management Systems, Inc.	00234	Accept Comment 58-109
58	23	F2006	Chapter 14	James H. Stannard, Stannard & Company	00283	Accept Comment 58-140

**Item # 8 NFPA 301 Merchant Vessels**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
301	1	A2007	20.13.2.1	Marcello M. Hirschler, GBH International	00292	Accept Comment 301-12	

Date Printed 5/30/2007

\*Designated Representative in accordance with 4.6.8.1 and /or 4.6.8.2 of NFPA's Regulation Governing Committee projects

**Table II A: Certified Amending Motions on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

301	2	A2007	7.3.4.5	Marcello M. Hirschler, GBH International	00290	Accept Comment	301-5
301	3	A2007	7.4, 7.4.1, 7.4.2, and 7.4.3	Marcello M. Hirschler, GBH International	00291	Accept Comment	301-6
301	4	A2007	7.4.1	Carl M. Ogburn, Chestnut Ridge Foam	00295	Accept Comment	301-8
301	5	A2007	Entire Document	Marcello M. Hirschler, GBH International	00289	Return entire Report	301-2

**Item # 9 NFPA 96 Venting Systems for Cooking Appliances**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
96	1	A2007	3.3.9 Certified Person	Mark Conroy, Brooks Equipment Co.	00315	Return a portion of a Report in the form of a proposal and related comment(s) 96-7	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 1**

NFPA Doc	#	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70	1	A2007	90.2(A)(2) FPN to (2)	Timothy M. Croushore, Allegheny Power	00359	Reject Comment 70-1-1	
70	2	A2007	90.2(B)(5)(b)	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake. Frederic P. Hartwell, Hartwell Electrical Services, Inc. (Log #399)	00348 00399	Reject Comment 70-1-3	Multiple Notices for a Single Motion per 2.4 of Convention Rules.
70	3	A2007	110.20 (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00398	Accept an Identifiable Part Comment 70-1-63  The Identifiable Part is: Accept only the first phrase of the third recommendation of the comment, which reads "Relocate the requirement as 110.28."	
70	4	A2007	110.26(C)(2) and (3)	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake.	00355	Reject Comment 70-1-92	
70	5	A2007	110.33(A)	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake.	00351	Reject Comment 70-1-99	



**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 2**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70	6	A2007	210.8(A)	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake.	00356	Accept Comment 70-2-22
70	7	A2007	210.8(A)	Wayne E. Morris, AHAM R. Cripps and/or W. Morris is the Desig. Rep* for Williams.	00385	Accept Comment 70-2-24
70	8	A2007	210.8(A)(2) and 210.8(A)(5)	Richard Cripps, Association of Home Appliance Mfrs. R. Cripps and/or W. Morris is the Desig. Rep* for O'Quinn.	00375	Accept Comment 70-2-29

**Related Motions:** Motions 70-6, 70-7 and 70-8 (logs 356, 385 and 375), while different in the means they employ, all seek to achieve the same action. Specifically, any one of the three motions, if successful would maintain exception number 2 to section 210.8(A)(2) and exception number 2 to section 210.8(a)(5). All three motions have been certified as proper. So as to eliminate multiple debates on the same proposed action, however, the following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once any one of the three motions is made and seconded, the other two will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 3**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 9	A2007	300.4(G)	Lawrence E. Roberts, WireGuard, Inc. L. Roberts is the Desig. Rep* for Smith.	00358	Accept as Modified by TC Comment	70-3-8
70 10	A2007	300.4(G)	Jody Ray Cook, Plugs & Switches, Inc.	00383	Accept Proposal	70-3-36
70 11	A2007	300.4(G) (New)	Carlo Compagnone, Compa Covers Inc.	00400	Accept Comment	70-3-13
70 12	A2007	590.8 (New)	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake.	00341	Accept Comment	70-3-90
70 13	A2007	725.82	Thomas P. Hammerberg, Automatic Fire Alarm Association, Inc. Fraser is the Desig. Rep* for Hammerberg.	00362	Accept Comment	70-3-133
70 14	A2007	760.82	Thomas P. Hammerberg, Automatic Fire Alarm Association, Inc. Fraser is the Desig. Rep* for Hammerberg.	00360	Accept Comment	70-3-166
70 15	A2007	760.9	Thomas P. Hammerberg, Automatic Fire Alarm Association, Inc. Fraser is the Desig. Rep* for Hammerberg.	00364	Accept Comment	70-3-148
70 16	A2007	760.15	Thomas P. Hammerberg, Automatic Fire Alarm Association, Inc. Fraser is the Desig. Rep* for Hammerberg.	00361	Accept Comment	70-3-151

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

70	17	A2007	760.32(B)(2), 760.32(B)(3), 760.32(B)(4), 760.61(A), 760.61(B)(1), and 760.61(C)	Thomas P. Hammerberg, Automatic Fire Alarm Association, Inc. Fraser is the Desig. Rep* for Hammerberg.	00363	Accept Comment 70-3-156
----	----	-------	---	--	-------	-------------------------

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 5**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 18	A2007	250.14	Wayne Robinson, Kenny Clamp LLC	00334	Return a portion of a Report in the form of a proposal and related comment(s) 70-5-47  (Proposal 70-5-90)	
70 19	A2007	250.50(A)	Paul E. Guidry, Fluor Enterprises, Inc.	00336	Accept Comment 70-5-77	
70 20	A2007	250.66(D)	Wayne Robinson, Kenny Clamp LLC	00335	Accept Comment 70-5-117	
70 21	A2007	250.68(A)	Donald R. Cook, Shelby County Dept. of Dev. Services	00377	Accept Comment 70-5-120	
70 22	A2007	250.94(1), (2), and (3)	Wayne Robinson, Kenny Clamp LLC	00332	Return a portion of a Report in the form of a proposal and related comment(s) 70-5-122  (Proposal 70-5-220)	
70 23	A2007	250.119	Noel Williams, Noel Williams Consulting	00337	Accept an Identifiable Part Comment 70-5-140  The Identifiable Part is: The entire proposed text in the comment except the words "or Chapter 8."	
70 24	A2007	250.119	Noel Williams, Noel Williams Consulting	00338	Reject Comment 70-5-141	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 6**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 25	A2007	310.6	Michael P. Walls, American Chemistry Council D. Weschler et al is the Desig. Rep* for Walls.	00318	Accept Comment 70-6-17	
70 26	A2007	310.6(1)	H. R. Stewart, HRS Consulting H. Stewart is the Desig. Rep* for McClung.	00339	Accept Proposal 70-6-13	
70 27	A2007	310.6 Exception	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake.	00345	Accept Comment 70-6-13	
70 28	A2007	310.6 Exception No. 2 (New)	David Wechsler, American Petroleum Institute D. Weschler is the Desig. Rep* for Hamer.	00402	Accept Comment 70-6-26	
70 29	A2007	310.7	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake.	00343	Accept Comment 70-6-29	
70 30	A2007	310.15(B)(2)(c)	Michael P. Walls, American Chemistry Council D. Weschler is the Desig. Rep* for Lewis & Walls.	00319	Accept Comment 70-6-48	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 7**

<b>NFPA Doc</b>	<b>#</b>	<b>Cycle</b>	<b>Affected Section of NFPA Document</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Log #</b>	<b>Certified Amending Motion</b>	<b>Motions Committee Notes or Comments</b>
70	31	A2007	334.12 Exception	William A. Wolfe, Steel Tube Institute of North America	00384	Accept Comment 70-7-27	
70	32	A2007	334.15(C)	Gerald H. Horn, J-Horn Electric, Inc.	00287	Accept Proposal 70-7-65	
70	33	A2007	382	Samuel LaDart, Eads, TN	00357	Accept Comment 70-7-55	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 8**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 34	A2007	342.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00397	Accept Comment 70-8-11	<p><b>Group Amending Motion (70-34).</b> Motions identified by log numbers 397, 396, 394, 395, 392, 393, 391, 389 and 390 taken together seek to maintain previous edition text in five different sections of the code. Generally, the text at issue concerns support of several types of conduit; the motions themselves should be consulted for a description of the precise action sought. All nine motions have been certified as proper. In addition, with the agreement of the authorized maker of the motions, these motions are being considered as dependent motions which will be debated and voted on by the assembly as a single up or down package. See NFPA Technical Meeting Convention Rules 2.3. Accordingly, the following procedure will be in effect for these motions at the Technical Session: the nine dependent motions will be grouped into a single "Group Amending Motion" identified as Motion 70-34 which, once made by the authorized person, will effectively place all nine dependent motions on the floor for debate and vote as a single up or down motion.</p>
	A2007	342.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00396	Reject Comment 70-8-8	
	A2007	344.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00394	Reject Comment 70-8-21	
	A2007	344.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00395	Accept Comment 70-8-24	
	A2007	352.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00392	Reject Comment 70-8-39	
	A2007	352.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00393	Accept Comment 70-8-41	
	A2007	355.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00391	Reject Comment 70-8-49b	
	A2007	358.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00389	Reject Comment 70-8-58	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

70	42	A2007	358.30(C) (New)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00390	Accept Comment 70-8-60	<b>Group Amending Motion:</b> Part of a group amending motion. See item 70-34 on previous page.
70	35	A2007	352.10(G)	Michael P. Walls, American Chemistry Council D. Weschler et al is the Desig. Rep* for Walls.	00316	Return a portion of a Report in the form of a proposal and related comment(s) 70-8-45a  (Proposal 70-8-68)	
70	36	A2007	352.100	Steve Tollefson, V.P. Engineering, CANTEX, Inc. Travis Lindsey, Travis Lindsey Coinsulting Services Inc. (Log 401)	00369 00401	Reject an Identifiable Part Comment 70-8-45a  The Identifiable Part is: The material shall be homogeneous without the use of foaming agents, except as permitted in 352.10(G), for direct burial and underground encased in concrete.	Multiple Notices for a Single Motion per 2.4 of Convention Rules.
70	37	A2007	Chapter 9, Table 1	Michael P. Walls, American Chemistry Council D. Weschler et al is the Desig. Rep* for Walls.	00317	Reject Comment 70-8-87	



**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 9**

<b>NFPA Doc</b>	<b>#</b>	<b>Cycle</b>	<b>Affected Section of NFPA Document</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Log #</b>	<b>Certified Amending Motion</b>	<b>Motions Committee Notes or Comments</b>
70	38	A2007	312.10(B) (New) and 314.40(D) (New)	Rod Belisle, NIETC	00370	Accept as Modified by TC Comment 70-9-42	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 10**

<b>NFPA Doc</b>	<b>#</b>	<b>Cycle</b>	<b>Affected Section of NFPA Document</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Log #</b>	<b>Certified Amending Motion</b>	<b>Motions Committee Notes or Comments</b>
70	39	A2007	240.91	Alan Manche, Schneider Electric / Square D	00410	Return a portion of a Report in the form of a proposal and related comment(s) 70-10-56  (Proposal 70-10-27)	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 12**

<b>NFPA Doc</b>	<b>#</b>	<b>Cycle</b>	<b>Affected Section of NFPA Document</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Log #</b>	<b>Certified Amending Motion</b>	<b>Motions Committee Notes or Comments</b>
70	40	A2007	647.7(A)(4)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00387	Accept an Identifiable Part Comment 70-12-88	
							The Identifiable Part is: Accept the first option as stated in the comment, which is to reject proposal 70-12-127.

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 13**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 41	A2007	480.5 (New)	James E. Brunssen, Telecordia Technologies, Inc.	00331	Reject Comment 70-13-21	
70 42	A2007	700.9(B)	Alan Manche, Schneider Electric / Square D	00409	Return a portion of a Report in the form of a proposal and related comment(s) 70-13-156  (Proposal 70-13-118)	
70 43	A2007	700.27	James E. Degnan, Sparling Electrical Engineering & Technology Consultants J. Degnan is the Desig. Rep* for Batie.	00407	Accept Comment 70-13-187	
70 44	A2007	701.18	James E. Degnan, Sparling Electrical Engineering & Technology Consultants J. Degnan is the Desig. Rep* for Batie.	00408	Accept Comment 70-13-233	
70 45	A2007	702.6 Exception	Neil F. LaBrake, Edison Electric Institute T. Croushore is the Desig. Rep* for LaBrake.	00342	Accept Comment 70-13-257	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 14**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 46	A2007	501.10(B)(1)(7)	Richard E. Lloyd, Sun Lakes, AZ	00330	Accept Comment 70-14-9	<b>Related Motions:</b> See Note below.
70 47	A2007	501.10(B)(1)(7)	J. Joseph Dodds, Trafford, PA	00340	Accept Comment 70-14-10	
70 48	A2007	501.140(A)(3)	Stephen V. Norako, EGS Electrical Group	00415	Accept Proposal 70-14-53	
70 49	A2007	502.115(B)(2)	Michael P. Walls, American Chemistry Council D. Weschler et al is the Design. Rep* for Walls	00320	Accept Comment 70-14-25	

**Related Motions.** Motions 70-46 and 70-47 (logs 330 and 340), while different in the means they employ, seek to achieve the same action. Specifically, both motions, if successful would maintain previous edition text for section 510.10(B)(1)(7). Both motions have been certified as proper. So as to eliminate multiple debates on the same proposed action, the following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: once any one of the two motions is made and seconded, the other two will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 15**

<b>NFPA Doc</b>	<b>#</b>	<b>Cycle</b>	<b>Affected Section of NFPA Document</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Log #</b>	<b>Certified Amending Motion</b>	<b>Motions Committee Notes or Comments</b>
70	50	A2007	517.26 and 517.3	James R. Duncan, Sparling Electrical Engineering & Technology Consultants Member of CMP15	00406	Accept Comment 70-15-35	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 16**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 51	A2007	770.24	Timothy P. McNeive, Thomas & Betts Corporation	00322	Accept Comment 70-16-29	<p><b>Group Amending Motion (70-51).</b> Motions identified by log numbers 322 through 329 taken together seek to delete the term "listed" in four different sections of the code as noted. The motions themselves should be consulted for a description of the precise action sought. All eight motions have been certified as proper. In addition, with the agreement of the authorized maker of the motions, these motions are being considered as dependent motions which will be debated and voted on by the assembly as a single up or down package. See NFPA Technical Meeting Convention Rules 2.3. Accordingly, the following procedure will be in effect for these motions at the Technical Session: the eight dependent motions will be grouped into a single "Group Amending Motion" identified as Motion 70-51 which, once made by the authorized person, will effectively place all eight dependent motions on the floor for debate and vote as a single up or down motion.</p>
	A2007	770.24	Timothy P. McNeive, Thomas & Betts Corporation	00323	Accept an Identifiable Part Comment 70-16-30  The Identifiable Part Is: Accept the deletion of the word "listed". Continue to reject the remainder of the comment.	
	A2007	800.24	Timothy P. McNeive, Thomas & Betts Corporation	00324	Accept an Identifiable Part Comment 70-16-111  The Identifiable Part Is: Accept the deletion of the word "listed". Continue to reject the remainder of the comment.	
	A2007	800.24	Timothy P. McNeive, Thomas & Betts Corporation	00325	Accept an Identifiable Part Comment 70-16-112  The Identifiable Part Is: Accept the deletion of the word "listed". Continue to reject the remainder of the comment.	
	A2007	820.24	Timothy P. McNeive, Thomas & Betts Corporation	00326	Accept Comment 70-16-213	
	A2007	820.24	Timothy P. McNeive, Thomas & Betts Corporation	00327	Accept an Identifiable Part Comment 70-16-214  The Identifiable Part Is: Accept the deletion of the word "listed". Continue to reject the remainder of the comment.	

Date Printed 5/18/2007

\*Designated Representative in accordance with 4.6.8.1 and /or 4.6.8.2 of NFPA's Regulation Governing Committee projects

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

A2007	830.24	Timothy P. McNeive, Thomas & Betts Corporation	00328	Accept Comment 70-16-294	<b>Group Amending Motion:</b> Part of a group amending motion. See item 70-51 on previous page.
A2007	830.24	Timothy P. McNeive, Thomas & Betts Corporation	00329	Accept an Identifiable Part Comment 70-16-295	

The Identifiable Part Is: Accept the deletion of the word "listed". Continue to reject the remainder of the comment.

70	52	A2007	770.154 FPN	James T. Dollard, IBEW Local 98	00403	Accept Comment 70-16-58	<b>Related Motions.</b> Motions 70-52, 70-53 and 70-54 (logs 403, 301 & 412) while different in the means they employ seek to achieve the same action. The following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once one of the three motions is made and seconded, the others will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.
70	53	A2007	770.154(A) FPN	Marcelo M. Hirschler, GBH International	00301	Accept Comment 70-16-68	
70	54	A2007	770.154(A) FPN	Harold C. Ohde, International Brotherhood of Electric Workers (IBEW)	00412	Accept Comment 70-16-62	

**Note on Standards Council Decisions.** Motions 70-52 through 70-54 (logs 403, 301 and 412) seek to delete the fine print note to code section 770.154(A). The Standards Council has clarified that the deletion of this fine print note is not prohibited by Standards Council Decision No. 05-24 (SC item no. 05-7-4, July 29, 2005), which directed the NEC project, in this revision cycle, to maintain the status quo in the NEC on the subject of cables in air handling spaces. See Standards Council Decision Nos. 06-03 (SC item no. 6-3-18, March 22, 2005) and 06-19 (SC item no. 06-7-33, July 28, 2006). These motions, therefore, are proper and have been certified.



**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

70	55	A2007	800.154 FPN	James T. Dollard, IBEW Local 98	00404	Accept Comment 70-16-146	<p><b>Related Motions.</b> Motions 70-55, 70-56 and 70-57 (logs 404, 298 &amp; 413) while different in the means they employ seek to achieve the same action. The following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once one of the three motions is made and seconded, the others will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.</p>
70	56	A2007	800.154(A) FPN	Marcelo M. Hirschler, GBH International	00298	Accept Comment 70-16-158	
70	57	A2007	800.154(A) FPN	Harold C. Ohde, International Brotherhood of Electric Workers (IBEW)	00413	Accept Comment 70-16-150	

**Note on Standards Council Decisions.** Motions 70-55 through 70-57 (logs 404, 298 and 413) seek to delete the fine print note to code section 800.154(A). The Standards Council has clarified that the deletion of this fine print note is not prohibited by Standards Council Decision No. 05-24 (SC item no. 05-7-4, July 29, 2005), which directed the NEC project, in this revision cycle, to maintain the status quo in the NEC on the subject of cables in air handling spaces. See Standards Council Decision Nos. 06-03 (SC item no. 6-3-18, March 22, 2005) and 06-19 (SC item no. 06-7-33, July 28, 2006). These motions, therefore, are proper and have been certified.

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

70	58	A2007	820.154(A) FPN	James T. Dollard, IBEW Local 98	00405	Accept Comment	70-16-253	<p><b>Related Motions.</b> Motions 70-58, 70-59 and 70-60 (logs 405, 300 &amp; 414) while different in the means they employ seek to achieve the same action. The following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: Once one of the three motions is made and seconded, the others will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.</p>
70	59	A2007	820.154(A) FPN	Marcelo M. Hirschler, GBH International	00300	Accept Comment	70-16-264	
70	60	A2007	820.154(A) FPN	Harold C. Ohde, International Brotherhood of Electric Workers (IBEW)	00414	Accept Comment	70-16-257	

**Note on Standards Council Decisions.** Motions 70-58 through 70-60 (logs 405, 300 and 414) seek to delete the fine print note to code section 820.154(A). The Standards Council has clarified that the deletion of this fine print note is not prohibited by Standards Council Decision No. 05-24 (SC item no. 05-7-4, July 29, 2005), which directed the NEC project, in this revision cycle, to maintain the status quo in the NEC on the subject of cables in air handling spaces. See Standards Council Decision Nos. 06-03 (SC item no. 6-3-18, March 22, 2005) and 06-19 (SC item no. 06-7-33, July 28, 2006). These motions, therefore, are proper and have been certified.

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 17**

<b>NFPA Doc #</b>	<b>Cycle</b>	<b>Affected Section of NFPA Document</b>	<b>Person(s) Authorized to Make the Motion</b>	<b>Log #</b>	<b>Certified Amending Motion</b>	<b>Motions Committee Notes or Comments</b>
70 61	A2007	680.26	Wayne Robinson, Kenny Clamp LLC	00333	Return a portion of a Report in the form of a proposal and related comment(s) 70-17-92  (Proposal 70-17-114a)	
70 62	A2007	680.26(B)(2)	Jeff Fitzloff, State of Idaho Division of Building Safety	00296	Accept Comment 70-17-97	

**Table II B: Certified Amending Motions on NFPA 70 (NEC) for the June 2007 Association Technical Meeting**

(Note: The motions are presented in the order of presentation recommended by the Motions Committee.)

**Panel 18**

NFPA Doc #	Cycle	Affected Section of NFPA Document	Person(s) Authorized to Make the Motion	Log #	Certified Amending Motion	Motions Committee Notes or Comments
70 63	A2007	406.4(D) Exception No. 2	Debra S. Rade, TayMac Corporation	00378	Return a portion of a Report in the form of a proposal and related comment(s) 70-18-9  (Proposal 70-18-19)	
70 64	A2007	406.4(D) Exception No. 2	Debra S. Rade, TayMac Corporation	00379	Reject Comment 70-18-9	<b>Related Motions:</b> See Note below.
70 65	A2007	406.4(D) Exception No. 2	Robert Miller, TayMac Corporation	00380	Accept Comment 70-18-10	
70 66	A2007	406.11	Robert A. Jones, IEC Texas Gulf Coast	00321	Accept Comment 70-18-32	

**Related Motions.** Motions 70-64 & 70-65 (logs 379 & 380), while different in the means they employ, both seek to achieve the same action. Specifically, if successful both would delete exception number 2 to section 406.4(D). Both motions have been certified as proper. So as to eliminate multiple debates on the same proposed action, however, the following procedure regarding the orderly and efficient consideration of the subject presented by the related motions will be in effect at the Technical Session: once any one of the two motions is made and seconded, the other will no longer be in order, and the single motion on the floor will serve as the representative motion for purposes of debate and vote on the proposed action. All persons wishing to participate in debate on the proposed action should, therefore, do so during the presentation of the representative motion.

**Table III A: NITMAMs on Documents (Except NFPA 70) for the June 2007 Association Technical Meeting That were NOT Certified.**

NFPA Doc	Cycle	Affected Section of NFPA Document	Person(s) Submitting NITMAM	Log #	NITMAM	Motions Committee Notes or Comments
25	F2006	14.5.2(3)	Michael A. Krieger, Pfizer Inc.	00280	Reject Proposal 25-199	Not Valid Motion: No comment.
58	F2006	3.3.11	Thomas A. Wilson, City of Winter Park	00242	Reject Comment 58-1	Not Valid Motion: Comment already rejected.
58	F2006	3.3.11	Thomas A. Wilson, City of Winter Park	00244	Reject Comment 58-3	Not Valid Motion: Comment already rejected.
58	F2006	3.3.11	Thomas A. Wilson, City of Winter Park	00245	Reject Comment 58-4	Not Valid Motion: Comment already rejected.
58	F2006	3.3.11	Thomas A. Wilson, City of Winter Park	00246	Reject Comment 58-5	Not Valid Motion: Comment already rejected.
58	F2006	3.3.11	Thomas A. Wilson, City of Winter Park	00247	Reject Comment 58-6	Not Valid Motion: Comment already rejected.
58	F2006	3.3.11, 5.7.6.4 and 6.17	Thomas A. Wilson, City of Winter Park	00248	Reject Comment 58-6	Not Valid Motion: Comment already rejected.
58	F2006	5.18.8	Thomas A. Wilson, City of Winter Park	00259	Reject Comment 58-68	Not Valid Motion: Comment already rejected.
58	F2006	5.18.8	Thomas A. Wilson, City of Winter Park	00260	Reject Comment 58-70	Not Valid Motion: Comment already rejected.
58	F2006	5.18.8	Thomas A. Wilson, City of Winter Park	00261	Reject Comment 58-71	Not Valid Motion: Comment already rejected.
58	F2006	6.17	Thomas A. Wilson, City of Winter Park	00263	Reject Comment 58-93	Not Valid Motion: Comment already rejected.
58	F2006	6.17	Thomas A. Wilson, City of Winter Park	00265	Reject Comment 58-95	Not Valid Motion: Comment already rejected.
58	F2006	6.17	Thomas A. Wilson, City of Winter Park	00266	Reject Comment 58-96	Not Valid Motion: Comment already rejected.
58	F2006	6.17	Thomas A. Wilson, City of Winter Park	00267	Reject Comment 58-97	Not Valid Motion: Comment already rejected.
58	F2006	6.17	Thomas A. Wilson, City of Winter Park	00277	Reject Comment 58-98	Not Valid Motion: Comment already rejected.
58	F2006	A.7.4.3.2(A)	Thomas A. Wilson, City of Winter Park	00274	Reject Comment 58-158	Not Valid Motion: Comment already rejected.
58	F2006	A.7.4.3.2(A)	Thomas A. Wilson, City of Winter Park	00275	Reject Comment 58-159	Not Valid Motion: Comment already rejected.

**Table III B: NITMAMs on NFPA 70 (NEC) for the June 2007 Association Technical Meeting That were NOT Certified.**

#	NFPA Doc	Affected Section of NFPA Document	Person(s) Submitting NITMAM	Log #	NITMAM	Motions Committee Notes or Comments
1	70	210.8(A)(2)	Charles Cook, Sump and Sewage Pump Manufacturers Association	00381	Reject Comment 70-2-31	This NITMAM which seeks to reject comment 70-2-31 is not being certified. In accordance with section 4.6.8.3(b)(5) of NFPA's Regulations Governing Committee Projects, a motion to reject a comment is only in order where an accepted comment modifies a proposal in the ROP. Comment 70-2-31 does not modify any proposals.
2	70	210.8(A)(2) and 210.8(A)(5)	Richard Cripps, Association of Home Appliance Mfrs.	00376	Return a portion of a Report in the form on identifiable part(s) of a proposal and related comment(s) 70-2-41	This NITMAM which seeks return a portion of the report in the form of an identifiable part of a proposal and related comment in not being certified. In accordance with section 4.6.8.3(c)(3) of NFPA's Regulations Governing Committee Projects, a portion of a proposal may only be returned when a comment results in further changes to the proposal. No accepted comments in the ROC result in further changes to proposal 70-2-41.
3	70	210.8(A)(5)	Charles Cook, Sump and Sewage Pump Manufacturers Association	00382	Reject Comment 70-2-33	This NITMAM which seeks to reject comment 70-2-33 is not being certified. In accordance with section 4.6.8.3(b)(5) of NFPA's Regulations Governing Committee Projects, a motion to reject a comment is only in order where an accepted comment modifies a proposal in the ROP. Comment 70-2-33 does not modify any proposals.
4	70	725.82(A) FPN	Marcelo M. Hirschler, GBH International	00304	Accept Comment 70-3-134	See Note 1 to Table III B.
5	70	760.81(C) FPN	Marcelo M. Hirschler, GBH International	00305	Accept Comment 70-3-164	See Note 1 to Table III B.
6	70	760.82(D) FPN	Marcelo M. Hirschler, GBH International	00306	Accept Comment 70-3-167	See Note 1 to Table III B.

#	NFPA Doc	Affected Section of NEPA Document	Person(s) Submitting NITMAM	Log #	NITMAM	Motions Committee Notes or Comments
7	70	647.7(A)(4)	Frederic P. Hartwell, Hartwell Electrical Services, Inc.	00388	Accept an Identifiable Part Comment 70-12-88	This NITMAM which seeks to accept an identifiable part of comment 70-12-88 is not being certified. In accordance with section 4.6.5(a)(1) of NFPA's Regulations Governing Committee Projects, the identifiable part of a proposal or comment is to be capable of being segmented into separate parts understandable to the voting membership. The specific action suggested by the NITMAM is unclear as it appears that the NITMAM is attempting to incorporate language from the substantiation of proposal 70-12-127.
8	70	800.2	Marcelo M. Hirschler, GBH International	00302	Accept Comment 70-16-84	See Note 1 to Table III B.
9	70	800.2	Marcelo M. Hirschler, GBH International	00303	Accept Comment 70-16-85	See Note 1 to Table III B.
10	70	800.2	Harold C. Ohde, International Brotherhood of Electric Workers (IBEW)	00367	Accept Comment 70-16-89	See Note 1 to Table III B.
11	70	820.2	Marcelo M. Hirschler, GBH International	00299	Accept Comment 70-16-193	See Note 1 to Table III B.
12	70	820.2	Harold C. Ohde, International Brotherhood of Electric Workers (IBEW)	00411	Accept Comment 70-16-194	See Note 1 to Table III B.

**Note 1 to Table IIIB:** The motion proposed by this NITMAM relates to the subject of cables in air handling spaces, and addresses action taken by the responsible NEC Panel to comply with Standards Council Decision No. 05-24 (SC item no. 05-7-4, July 29, 2005). Standards Council Decision No. 05-24 directed the NEC project to maintain the status quo in the NEC on the subject of cables in air handling spaces until the relevant issues have been resolved by the project with primary jurisdiction over the subject, namely the NFPA 90A project on air conditioning and ventilating systems. Through this Decision, the Standards Council has effectively removed issues relating to cables in air handling spaces from the table for consideration by the NEC project in this revision cycle. Accordingly (and consistent with the treatment of this subject during the last revision cycle when a similar directive was in effect), motions relating to this subject are off the table for consideration at the 2007 Association Technical Meeting and are, therefore, being ruled out of order.