FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #1 NFPA 501, *Standard on Manufactured Housing* F2008

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
501-1	2:26:00 PM 2:32:08 PM	5.3.2.6	Marcelo Hirschler, GBH International	Accept Comment 501-7	Motion Passed (63:35)
501-2	2:32:28 PM 2:41:48 PM	5.3.2.6	Shawn Martin, Plumbing Manufacturers Institute	Accept Comment 501-8	Motion Failed
501-3	2:42:00 PM 2:43:00 PM	5.4	Marcelo Hirschler, GBH International	Accept Comment 501-10	Motion Passed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #2 NFPA 400, *Hazardous Materials Code* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
400-1	2:44:58 PM 3:04:55 PM	1.1.2.2	Michael P. Walls, Arlington, VA Wechsler is the Desig. Rep.* for Walls	Accept Comment 400-12	Motion Failed
400-2	3:05:58 PM 3:17:54 PM	1.3.1.1	Michael P. Walls, Arlington, VA Wechsler is the Desig. Rep.* for Walls Richard S. Kraus, Petroleum Safety Consultants	Accept Comment 400-16	Motion Failed
400-3	3:18:04 PM 3:23:48 PM	Chapter 5 and 6.1.1.1 and 6.1.1.2	Michael P. Walls, Arlington, VA Wechsler is the Desig. Rep.* for Walls	Accept Comment 400-60	Motion Failed
400-4	3:24:30 PM 3:31:41 PM	5.4.1.3	Richard S. Kraus, Petroleum Safety Consultants	Accept Comment 400-89	Motion Failed
400-5	3:32:20 PM 3:40:27 PM	Chapter 21	Michael P. Walls, Arlington, VA Wechsler is the Desig. Rep.* for Walls	Accept Comment 400-218	Motion 400-5 failed. Motion 400-6 not pursued since it is a Related Motion to 400-5.
400-6		Chapter 21	Richard S. Kraus, Petroleum Safety Consultants	Accept Comment 400-214	

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #3 NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
20-1	3:42:29 PM 4:04:18 PM	4.3.1	Kenneth E. Isman, National Fire Sprinkler Association	Return a portion of a Report in the form on identifiable part of Proposal 20-3 and related Comment 20-2. The Identifiable part that is returned reads as follows: "4.3.1 Fire pumps operating in series and their controllers shall be located within the same fire pump room."	Motion passed
20-2	4:05:10 PM	9.2.3.4	R. Schneider, Lancaster, SC	Accept Comment 20-48	Motion not pursued
20-3	4:05:55 PM 4:26:25 PM	10.7	Kenneth E. Isman, National Fire Sprinkler Association	Accept Comment 20-66	Motion 20-3 passed. Motion 20-4 not pursued since it is a Related Motion to 20-3.
20-4		10.7 and A.10.7	Manuel J. DeLerno, St.. Charles, IL	Accept Comment 20-67	

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #4 NFPA 13, *Standard for the Installation of Sprinkler Systems* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
13-1	4:44:35 PM 4:51:10 PM	6.5.1	Leonard R. Swantek, Victaulic Company of America	Reject Comment 13-34	Motion failed
13-2	4:51:50 PM 4:55:58 PM	7.1.2.1	Cecil Bilbo, Jr., National Fire Sprinkler Association Isman is the Desig. Rep.* for Bilbo	Accept Comment 13-46	Motion failed
13-3	4:56:20 PM	7.1.2.1	Kenneth E. Isman, National Fire Sprinkler Association	Reject Comment 13-44	Motion not pursued
13-4	4:56:49 PM 5:00:13 PM	Table 8.6.2.2.1(a)	Cecil Bilbo, Jr., National Fire Sprinkler Association Isman is the Desig. Rep.* for Bilbo	Accept Comment 13-84	Motion passed
13-5	5:00:54 PM 5:08:04 PM	8.15.3.2.5	David J. Burkhart, Code Consultants, Inc.	Accept Comment 13-136	Motion passed (78:56)
13-6	5:08:50 PM 5:27:30 PM	8.15.8.1.1	Ronald G. Nickson, Washington, DC Additional Submitters: Marshall Klein, Jeff Shapiro	Reject Comment 13-141	Motion passed (86:63)
13-7	5:28:10 PM 5:38:37 PM	8.17.4.1	David J. Burkhart, Code Consultants, Inc.	Accept Comment 13-104	Motion failed
13-8	5:39:21 PM 5:42:37 PM	9.3.2.3(6)	Kenneth E. Isman, National Fire Sprinkler Association	Reject Comment 13-173	Motion failed
13-9	5:43:10 PM 5:45:55 PM	A.9.3.2.4	Kenneth E. Isman, National Fire Sprinkler Association	Return a portion of a Report in the form of a Proposal 13-510(b) and related Comment 13-291	Motion failed
13-10	5:46:23 PM 5:53:39 PM	A.8.16.4.2.2	Kenneth E. Isman, National Fire Sprinkler Association	Reject Comment 13-47	Motion failed
13-11	5:54:20 PM 5:55:51 PM	A.22.4.4.5.1	Kenneth E. Isman, National Fire Sprinkler Association	Reject an Identifiable Part of Comment 13-302. The rejection of the identifiable part results in reinstating Figure A.22.4.4.5.1 (Moody Diagram) and Table A.22.4.4.5.1 (aged pipe table) from the 2007 edition.	Motion passed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #5 NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
13D-1	6:31:28 PM 6:45:27 PM	5.2.1.3	Jonathan C. Bittenbender, REHAU Inc. Bittenbender is the Desig. Rep.* for Cabral	Accept Proposal 13D-27	Group Amending Motion failed
		5.2.5.3	Jonathan C. Bittenbender, REHAU Inc. Bittenbender is the Desig. Rep.* for Cabral	Accept Proposal 13D-30	
13D-2	5:57:48 PM 6:30:37 PM	5.2.1.3 and 5.2.5.3	Ronald G. Nickson, Washington, DC Additional Submitters: Marshall Klein, Jeff Shapiro and	Reject Comment 13D-18	Motion passed (56:44)
		5.2.1.3 and 5.2.5.3	Jonathan C. Bittenbender, REHAU Inc.		
13D-3	6:46:45 PM	5.2.1.3 and 5.2.5.3	Jonathan C. Bittenbender, REHAU Inc.	Reject Comment 13D-19	Motions 13D-3 and 13D-4 not pursued since they are Related Motions to 13D-2.
13D-4		5.2.1.3 and 5.2.5.3	Jonathan C. Bittenbender, REHAU Inc.	Reject Comment 13D-20	
13D-5	6:47:32 PM 7:01:13 PM	7.6	Kenneth E. Isman, National Fire Sprinkler Association	Accept Comment 13D-27	Motion failed (45:56)

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #6 NFPA 52, *Vehicular Fuel Systems Code* F2008

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
52-1	8:17:15 AM 8:28:30 AM	Table 9.3.1.3 (Extract from 55:10.3.2.2.1) and related text	Larry Fluer, Fluer, Inc. Rep. Compressed Gas Association	Accept Comment 52-34	Motion passed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #7 NFPA 909, *Code for the Protection of Cultural Resources Properties – Museums, Libraries, and Places of Worship* F2008

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
909-1	8:29:30 AM	9.12.19	Marcelo Hirschler, GBH International	Accept Comment 909-7	Motion not pursued
909-2	8:30:00 AM	9.12.26.1	Marcelo Hirschler, GBH International	Accept Comment 909-8	Motion not pursued

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #8 NFPA 99, *Standard for Health Care Facilities* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
99-1	8:31:35 AM 8:40:15 AM	Chapter 1	Stephen M. Lipster, Columbus, OH	Return a portion of a Report in the form of Proposal 99-6a and related Comment 99-2.	Motion failed
99-2	8:40:45 AM 9:17:38 AM	3.3.185, Wet Locations, A.3.3.185, 4.3.2.2.8.3 and A.4.3.2.2.8.3	James S. Peterkin, Heery International	Return a portion of a Report in the form of Proposal 99-68 and Comment 99-93. The return of the report results in the return of the definition, *wet location*, and associated annex, to previous edition text.	Motion failed
99-3	9:18:08 AM 9:33:55 AM	Chapter 4	Stephen M. Lipster, Columbus, OH	Return a portion of a Report in the form of Proposal 99-73a and related Comment 99-6. The return of the report results in the deletion of: a new definition of *Basic Care Rooms* and associated annex material; the modification of the definitions *Critical Care Areas* and *General Care Areas* and associated annex material; and the deletion of the electrical requirements specified for *Basic Care Rooms*, *Critical Care Areas* and *General Care Areas*.	Motion failed (42:50)
99-4	9:34:34 AM 9:59:26 AM	4.4.2.1.2, 4.5.2.2.2, and 4.6.2.2.2	Malcolm Allison, National Electric Fuse Association	Accept Comment 99-408	Motion failed (40:46)
99-5	10:00:02 AM 10:17:10 AM	5.1.3.4.2	Simon Robitaille, Sante-Foy, Quebec	Accept Comment 99-434	Motion failed
99-6	10:27:43 AM	X.8.2	James K. Lathrop, Koffel Associates, Inc.	Return a portion of a Report in the form of identifiable part of Proposal 99-446 and related Comments 99-583, 99-587, 99-588, 99-589, and 99-596. The identifiable part is to return all of Section X.8.2.	Motion not pursued

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #8 NFPA 99, *Standard for Health Care Facilities* A2009 *(continued)*

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
99-7	10:17:55 AM 10:27:27 AM	Chapter X, *Features of Fire Protection*	James K. Lathrop, Koffel Associates, Inc.	Return a portion of a Report in the form of a Proposal 99-446 and related Comments 99-583, 99-587, 99-588, 99-589, and 99-596. The effect is the return of entire Chapter X, currently shown as Chapter 15, *Features of Fire Protection*.	Motion passed
99-8	10:29:53 AM 10:54:23 AM	5.1.10.10.13	Felix Mummolo, Smart Tap Inc.	Return Entire Report	Motion passed (73:50)

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #9 NFPA 130, *Standard for Fixed Guideway Transit and Passenger Rail Systems* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
130-1	11:15:22 AM 11:24:59 AM	3.3.x Plenum (New) and A.7.7.7	Marcelo M. Hirschler, GBH International	Accept Comment 130-11	Motion failed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #10 NFPA 80, *Standard for Fire Doors and Other Opening Protectives* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
80-1	11:26:48 AM 11:31:20 AM	17.2.2	Joshua W. Elvove, US General Services Administration Frable and Larrimer Desig. Rep.* for Elvove	Accept Comment 80-10	Motion passed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #11 NFPA 105, *Standard for Smoke Door Assemblies and Other Opening Protectives* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
105-1	11:32:12 AM 11:37:42 AM	6.5.5 and A.6.5.2	Joshua W. Elvove, US General Services Administration Frable and Larrimer are the Desig. Reps.* for Elvove	Accept an identifiable part of Proposal 105-4. The acceptance of the identifiable part results in the addition of an annex note and asterisk to 6.5.2, the deletion of text in 6.5.5, and no change to 6.6.5.	Motion passed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #12 NFPA *72®, National Fire Alarm Code* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
72-1	11:40:30 AM 11:46:37 AM	Entire Document	Dave Frable, U.S. General Services Administration	Reject an Identifiable Part of Comment 72-30. The rejection of the identifiable part results in the removal of the reserved chapters added in the TCC Note.	Motion failed
72-2	11:47:00 AM	3.3.200.1 Public Switched Telephone Network (New)	Roy Perry, CableLabs	Accept Proposal 72-60	Motion not pursued
72-3		3.3.200.1 Public Switched Telephone Network (New)	Roy Perry, CableLabs	Accept Proposal 72-60 as modified by the TC action.	Motion not pursued
72-4		4.4.3.7.2	Raymond A. Grill, Arup Fire	Accept Comment 72-95	Motion not pursued
72-5		4.4.4.4.8	Dave Frable, U.S. General Services Administration	Reject Comment 72-115	Motion not pursued
72-6	11:48:40 AM 12:22:21 PM	4.4.5 Exception No. 2	Dave Frable, U.S. General Services Administration	Reject Comment 72-150	Motion 72-6 failed. Motion 72-7 not pursued since it is a Related Motion to 72-6.
72-7		4.4.5 Exception No. 2	Dave Frable, U.S. General Services Administration Frable is the Desig. Rep.* for Decker	Accept Comment 72-145	
72-8	12:22:55 PM 12:33:37 PM	4.4.7.1.16	Thomas P. Hammerberg, Automatic Fire Alarm Association, Inc.	Accept Comment 72-164	Motion passed
72-9	12:34:30 PM 12:46:04 PM	6.8.5.1.2	Joshua W. Elvove, US General Services Administration Frable and Larrimer are the Desig. Reps.* for Elvove.	Reject Comment 72-223	Motion 72-9 failed. Motion 72-10 not pursued since it is a Related Motion to 72-9.
72-10		6.8.5.1.2	Joshua W. Elvove, US General Services Administration Frable and Larrimer are the Desig. Reps.* for Elvove.	Reject Comment 72-224	
72-11	12:46:36 PM 12:55:32 PM	6.9.10.2.1	Vic Humm, Vic Humm & Associates	Accept Comment 72-235	Motion passed
72-12	12:56:53 PM 1:18:39 PM	7.4.6	Scott R. Edwards, Gentex Corporation	Accept Comment 72-303	Motion 72-12 failed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #12 NFPA *72®, National Fire Alarm Code* A2009

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
72-13	1:19:21 PM 1:27:45 PM	7.4.6	Scott R. Edwards, Gentex Corporation	Accept Comment 72-304	Motions 72-13 and 72-14 not pursued since they are Related Motions to 72-12.
72-14		7.4.6	Scott R. Edwards, Gentex Corporation	Accept Comment 72-305	

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #12 NFPA *72®, National Fire Alarm Code* A2009 *(continued)*

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
72-15	1:28:01 PM 1:30:25 PM	8.5.2	Daniel G. Decker, Safety Systems, Inc.	Accept Comment 72-328	Motion failed
72-16	1:40:42 PM 1:50:05 PM	Table 10.4.2.2(23)	Joshua W. Elvove, US General Services Administration Frable and Larrimer are the Desig. Reps.* for Elvove.	Accept Comment 72-388	Motion failed (50:66)
72-17	1:50:59 PM 1:58:11 PM	Table 10.4.4(15)(l)	Joshua W. Elvove, US General Services Administration Frable and Larrimer are the Desig. Reps.* for Elvove.	Reject an Identifiable Part of Comment 72-394. The rejection of the identifiable part results in the deletion from the table the proposed new (15)(1)(6), which reads: "Fire pump supervisory indicating devices – (with a quarterly test frequency - same as current)."	Motion passed
72-18	1:58:47 PM 2:08:24 PM	10.4.6.1	John Drucker, Fire Marshals Office - Borough of Red Bank, NJ	Accept Comment 72-405	Motion passed (70-67)
72-19	2:09:43 PM 2:24:56 PM	12.3.5	Dave Frable, U.S. General Services Administration	Return a portion of a Report in the form of Proposal 72-571a and related Comment 72-452.	Motion 72-19 failed. Motions 72-20 and 72-21 not pursued since they are Related Motions to 72-19.
72-20		12.1.6 [renumbered as 12.3.5 in Comment 72-452]	Dave Frable, U.S. General Services Administration	Return a portion of a Report in the form of Proposal 72-571a and related Comment 72-453.	
72-21		12.1.6 [renumbered as 12.3.5 in Comment 72-452]	Dave Frable, U.S. General Services Administration	Return a portion of a Report in the form of Proposal 72-571a and related Comment 72-454.	
72-22	2:25:51 PM 2:27:09 PM	12.1.6.1.1	Denise L. Pappas, Valcom, Inc.	Accept an Identifiable Part of Comment 72-457. The acceptance of the identifiable part results in the reinstatement of 12.1.6.1.1, which reads as follows: "Refer to the 2010 Annex C for previous nomenclature and cross reference."	Motion passed

FINAL – Floor Action on Certified Amending Motions on Documents for the June 2009 Association Technical Meeting

Document #12 NFPA *72®, National Fire Alarm Code* A2009 *(continued)*

Motion Seq #	Time	Section/ Para	Person(s) Authorized to Make the Motion	Certified Amending Motion	Floor Action
72-23	2:28:05 PM 2:33:32 PM	12.4.2.20.3	Joseph A. Simone, US Department of the Navy	Reject an Identifiable Part of Comment 72-450. The rejection of the identifiable part results in the deletion of 12.4.2.20.3, which reads as follows: "Strobes used solely for mass notification shall be amber in color."	Motion 72-23 passed. Motion 72-24 not pursued since it is a Related Motion to 72-23.
72-24		12.2.2.28.3	Denise L. Pappas, Valcom, Inc.	Accept an Identifiable Part of Comment 72-486. The acceptance of the identifiable part results in the deletion of 12.2.2.28.3, which reads as follows: "Strobes used solely for mass notification shall be amber in color."	
72-25	2:33:48 PM	12.2.11.5.3	Dave Frable, U.S. General Services Administration Frable is the Desig. Rep.* for Remke	Accept Comment 72-495	Motion not pursued
72-26	2:34:16 PM 2:43:28 PM	A.4.4.5	Thomas P. Hammerberg, Automatic Fire Alarm Association, Inc.	Reject Comment 72-527	Motion passed