



RESEARCH FOUNDATION

RESEARCH FOR THE NFPA MISSION

Errata

Report:

Fire Safety Challenges of Tall Wood Buildings – Phase 2: Task 2 & 3 – Cross Laminated Timber Compartment Fire Tests

Author(s)

Joseph Su and Pier-Simon Lafrance
National Research Council of Canada
Ottawa, Ontario, Canada

Matthew Hoehler and Matthew Bundy
National Institute of Standards and Technology
Gaithersburg, MD USA

February 2018

Errata No.: FPRF-2018-01-01

Reference:

Erratum

This is to correct typos in the heat flux equation in Task 2&3 Report FPRF-2018-01 (i.e. NRC A1-010659.1). On page 40, the sign in front of the second term of the heat flux equation should be minus (not plus) and the units of heat flux are W/m^2 (not W). The corrected text should read:

The incident heat flux at the plate thermometer at step i ($[\dot{q}_{inc}'']^i$, in W/m^2) is calculated using the measured temperature of the plate thermometer (T_{PT} , in K) and the gas temperature near the plate thermometer (T_{gas} , in K) as follows:

$$[\dot{q}_{inc}'']^i = \sigma [T_{PT}^4]^i - \frac{(h + K_{PT}) ([T_{gas}]^i - [T_{PT}]^i) - C_{PT} \frac{[T_{PT}]^{i+1} - [T_{PT}]^{i-1}}{[t]^{i+1} - [t]^{i-1}}}{\epsilon_{PT}}$$

The published results in both the report and data sets for heat flux are correct and not affected by the typos in the body of the report.

Issue date: April 22, 2020

Phone: 617-984-7281

E-mail: foundation@nfpa.org

Copyright © 2020 All Rights Reserved