



RESEARCH FOUNDATION

RESEARCH FOR THE NFPA MISSION

Errata

Report:

Fire Hazard Assessment of Lead-Acid Batteries

Author(s)

Trent Parker, Larissa Obeng
and Qingsheng Wang, Ph.D., PE CSP

Mary Kay O'Connor Process Safety Center
Artie McFerrin Department of Chemical Engineering
Texas A&M University, College Station, Texas, USA

Date

July 2020

Errata No.: FPRF-2020-08-01

Reference:

Page 10, last row

NRG Power Plant Fire	December 18, 2019 in Milford, CT	-Batteries overheated, causing electrical short that resulted in bank of 50 lead acid batteries catching fire ¹²	-Loss of battery bank	250 V DC battery bank containing 50 batteries	Battery bank burning with flames 2-3 feet high 15-20 feet high
-------------------------	--	---	--------------------------	--	--

Issue date: December 7, 2020

Phone: 617-984-7281

E-mail: foundation@nfpa.org

Copyright © 2020 All Rights Reserved