



Tentative Interim Amendment

# NFPA 111

## *Standard on Electrical Energy Emergency and Standby Power Systems* 2016 Edition

**Reference:** Table 4.2.2

**TIA 16-1**

(SC 15-8-23 / TIA Log #1175)

**Note:** Text of the TIA was issued and incorporated into the document prior to printing, therefore no separate publication is necessary.

1. Revise Table 4.2.2 to read as follows:

**Table 4.2.2 Types of SEPSS**

Type	Interruption Time
Type O	No interruptions — UPS carrying load, 0.0 sec
Type U	UPS system with utility as preferred source
Type A	0.25 cycle: 0.0042 sec
Type B	1.0 cycle: 0.0167 sec
Type 10	10 sec
Type M	Manual stationary or nonautomatic — no time limit

**Issue Date:** August 19, 2015

**Effective Date:** September 8, 2015

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/codelist](http://www.nfpa.org/codelist))

Copyright © 2015 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION