

**Second Correlating Revision No. 3-NFPA 30-2013 [Section No.****2.3.1]****2.3.1** API Publications.

American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005-4070.

API Specification 12B, *Bolted Tanks for Storage of Production Liquids*, 15th edition, 2008.

API Specification 12D, *Field Welded Tanks for Storage of Production Liquids*, 11th edition, 2008.

API Specification 12F, *Shop Welded Tanks for Storage of Production Liquids*, 12th edition, 2008.

API 620, *Recommended Rules for the Design and Construction of Large, Welded, Low-Pressure Storage Tanks*, 11th edition, ~~2008~~ Addendum 2, 2010 .

API Standard 650, *Welded Steel Tanks for Oil Storage*, 11th edition, ~~2007~~ Addendum 2, 2009 .

API Standard 653, *Tank Inspection, Repair, Alteration, and Reconstruction*, 4th edition, ~~2009~~ 2012 .

API Standard 2000, *Venting Atmospheric and Low-Pressure Storage Tanks*, 5th edition, 1998.

API 2350, *Overfill Protection for Storage Tanks in Petroleum Facilities*, ~~3rd~~ 4th edition, ~~2005~~ 2012 .

Submitter Information Verification

Submitter Full Name: Robert Benedetti

Organization: National Fire Protection Assoc

Street Address:

City:

State:

Zip:

Submittal Date: Tue Nov 05 10:09:09 EST 2013

Committee Statement

Committee Statement: Second Correlating Revision No. 3 deletes the citations to API RP 752 and API RP 753 because their references have been removed from Subsection 17.3.1 and relocated to Annex A. The citations to both already exist in Annex I.



Second Correlating Revision No. 1-NFPA 30-2013 [Section No. 17.3.1]

17.3.1 *

[Global SCR-2](#) [Hide Deleted](#)

Liquid processing operations shall be located and operated so that they do not constitute a significant fire or explosion hazard to life, to property of others, or to important buildings or facilities within the same plant.

Submitter Information Verification

Submitter Full Name: Robert Benedetti
Organization: National Fire Protection Assoc
Street Address:
City:
State:
Zip:
Submittal Date: Tue Nov 05 09:46:50 EST 2013

Committee Statement

Committee Statement: This Second Correlating Revision deletes the mandatory references to API RP 752 and API RP 753 and replaces them with an asterisk leading to Annex text that will contain these citations. (See Second Correlating Revision No. 2.) The reason for so doing is that these references contain both mandatory and non-mandatory provisions, the latter not being enforceable and, therefore, not appropriate to cite in the body of the code.

[SR-3-NFPA 30-2013](#)



Second Correlating Revision No. 2-NFPA 30-2013 [New Section after A.17.1.1]

[A.17.3.1](#)

Information concerning the location of processing operations can be found in API RP 752, *Management of Hazards Associated with Location of Process Plant Buildings* and API RP 753, *Management of Hazards Associated with Location of Process Plant Portable Buildings*.

Submitter Information Verification

Submitter Full Name: Robert Benedetti
Organization: National Fire Protection Assoc
Street Address:
City:
State:
Zip:
Submittal Date: Tue Nov 05 09:56:48 EST 2013

Committee Statement

Committee Statement: This Second Correlating Revision is a companion to Second Correlating Revision No. 1 and effects the relocation of the citations to API RP 752 and API RP 753 from the body of the code to Annex A for the reasons explained in Second Correlating Revision No. 1.