



Tentative Interim Amendment

# NFPA<sup>®</sup> 70

## National Electrical Code<sup>®</sup> 2014 Edition

**Reference:** 517.41(E)

**TIA 14-7**

(SC 14-10-2 / TIA Log #1157)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70<sup>®</sup>, *National Electrical Code*<sup>®</sup>, 2014 edition. The TIA was processed by the NEC<sup>®</sup> Code-Making Panel 15 and the National Electrical Code<sup>®</sup> Correlating Committee, and was issued by the Standards Council on October 28, 2014, with an effective date of November 17, 2014.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Revise Article 517.41(E) to read as follows:*

**(E) Receptacle Identification.** The cover plates for the electrical receptacles or the electrical receptacles themselves supplied from the essential electrical system shall have a distinctive color or marking so as to be readily identifiable. [99:6.5.2.2.4.2]

**Issue Date:** October 28, 2014

**Effective Date:** November 17, 2014

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/codelist](http://www.nfpa.org/codelist))

Copyright © 2014 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION