



Errata

NFPA 70E[®]

Standard for Electrical Safety in the Workplace[®]

2012 Edition

Reference: Various

Errata No.: 70E-12-1

The National Electrical Code Correlating Committee notes the following in the 2012 edition of NFPA 70E[®], *Standard for Electrical Safety in the Workplace[®]*.

1. General **Throughout the document:** Wherever Annex B through Annex P have been referenced, add the word “Informative” before the word “Annex”. Revise all references to “Informative Annex A” to “Annex A.”
2. Page 70E-24 **Table 130.4(C)(a):** Revise 0.1 m in row 7, column 5 to 0.7 m
3. Page 70E-37 **Note 3 to Table 130.7(C)(15)(a):** Revise 130.8(C)(7) and 130.8(D) to 130.7(C)(7)(a) and 130.7(D)(1) respectively
4. Page 70E-37 **Note 5 to Table 130.7(C)(15)(a):** Revise the fifth sentence to read - Working distance was 18 in. (455 mm)
5. Page 70E-38 **Note b to Table 130.7(C)(15)(b):** Revise by deleting the phrase at the end of the note – “, and the rubber gloves chosen are required to be arc rated to the potential exposure level of the hazard/risk category”
6. Page 70E-40 **Table 130.7(C)(16), Note 1:** Revise Table 130.7(C)(9) to Table 130.7(C)(15)(a) and Table 130.7(C)(15)(b)
7. Page 70E-41 **Title of 130.8:** Delete “Uninsulated”
8. Page 70E-52 **320.3(C)(3)(c):** Revise 110.7(F) to 110.3(F)
9. Page 70E-62 **C.2.1.2 Column 2:** Revise “plus 102 mm (4.0 in.)” to read “plus 100 mm (4.0 in.)”
10. Page 70E-63 **Table D.1:** Delete row D.8 in its entirety
11. Page 70E-85 **Table H.3(b), Category – Greater than 12 cal/cm², , Other personal protective equipment, fifth row:** Delete the words “Arc-rated gloves or” and capitalize the word “Rubber”
12. Page 70E-98 **Informative Annex P:** Revise OSHA 18001 to OHSAS 18001

Issue Date: August 28, 2012

(Note: Electronic products and pamphlet reprints may have these errata incorporated. For current information about the NFPA Codes and Standards, including errata, please see www.nfpa.org/codelist)