



Tentative Interim Amendment

NFPA[®] 20

Standard for the Installation of Stationary Pumps for Fire Protection

2019 Edition

Reference: 10.10.3.5

TIA 19-1

(TIA Log #1389)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 2019 edition. The TIA was processed by the Technical Committee on Fire Pumps, and was issued by the Standards Council on November 6, 2018, with an effective date of November 26, 2018.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Revise 10.10.3.5 to read as follows:*

10.10.3.5 ~~When the variable speed pressure limiting control is bypassed, automatic shutdown of the controller shall be as permitted by 10.5.4.2.~~ When the manual selection means required in 10.10.7.3 is used to initiate a switchover from variable speed to bypass mode, if the pump is running in the variable speed mode and none of the conditions in 10.10.3 that require the controller to initiate the bypass operation exist, the controller shall be arranged to provide a restart delay to allow the motor to be de-energized before it is re-energized in the bypass mode.

Issue Date: November 6, 2018

Effective Date: November 26, 2018

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2018 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION