



Tentative Interim Amendment

NFPA[®] 58

Liquefied Petroleum Gas Code

2017 Edition

Reference: 6.13.3.3(new)
TIA 17-1
(SC 18-4-3 / TIA Log #1350)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 58, *Liquefied Petroleum Gas Code*, 2017 edition. The TIA was processed by the Technical Committee on Liquefied Petroleum Gas Code, and was issued by the Standards Council on April 10, 2018, with an effective date of April 30, 2018.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Add a new paragraph 6.13.3.3 to read as follows:*

6.13.3.3 Temperature-sensitive elements of internal valves shall not be painted or have any ornamental finishes applied after manufacture.

Issue Date: April 10, 2018

Effective Date: April 30, 2018

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2018 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION