



Tentative Interim Amendment

NFPA 70®

National Electrical Code®

2014 Edition

Reference: 690.12(2)

TIA 14-10

(SC 16-8-13 / TIA Log #1223)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70®, *National Electrical Code®*, 2014 edition. The TIA was processed by the NEC Code-Making Panel 4 and the Correlating Committee on National Electrical Code, and was issued by the Standards Council on August 4, 2016, with an effective date of August 24, 2016.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Revise 690.12(2) to read as follows:

(2) Controlled conductors shall be limited to no more than 30 volts and 240VA within 30 seconds of rapid shutdown initiation.

Issue Date: August 4, 2016

Effective Date: August 24, 2016

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2016 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION