



Tentative Interim Amendment

NFPA[®] 72[®]

National Fire Alarm and Signaling Code[®]

2016 Edition

Reference: 29.8.3.4(5)

TIA 16-1

(SC 18-8-23 / TIA Log #1345)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 72[®], *National Fire Alarm and Signaling Code[®]*, 2016 edition. The TIA was processed by the Technical Committee on Single- and Multiple-Station Alarms and Household Signaling Systems, and the Correlating Committee on Signaling Systems for the Protection of Life and Property, and was issued by the Standards Council on August 14, 2018, with an effective date of September 3, 2018.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Revise 29.8.3.4(5) to read as follows:*

29.8.3.4(5) Effective January 1, ~~2019~~2022, smoke alarms and smoke detectors used in household fire alarm systems installed between 6 ft (1.8 m) and 20 ft (6.1 m) along a horizontal flow path from a stationary or fixed cooking appliance shall be listed for resistance to common nuisance sources from cooking.

Issue Date: August 14, 2018

Effective Date: September 3, 2018

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2018 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION